

Water Sampling – Lancaster High School Final Report

Stohl Environmental
3860 California Road Orchard Park, New York 14127
Phone: 716-312-0070 Fax: 716-312-8092
www.stohlenvironmental.com

December 15, 2020

Mr. Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, NY 14086

Regarding: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:
Lancaster High School – 1 Forton Drive, Lancaster, New York.

This report is prepared to assist the District in complying with the requirements of New York State regulations, Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the New York State "Action Level of 15 parts per billion (p.p.b)".

The Investigation and Sampling was performed on October 17, 2020. The Protocol for the Investigation followed the requirements of New York State regulations as well as United States Environmental Protection Agency Technical Guidance "3 T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 25 sources of potable water in the High School have been identified as having lead concentration in water above the New York State Action Level of 15 parts per billion. To comply with New York State regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

"Signature of Eric Henderson Jr."
Senior Project Manager

Investigation and Sampling of Sources of Potable Water for Lead Concentrations Prepared for: Lancaster Central School District Prepared by:

Stohl Environmental
3860 California Road
Orchard Park, New York 14127
Phone (716) 312-0070 Fax (716) 312-8092
www.stohlenvironmental.com

Conditions as of October 17, 2020

Summary Tabulation Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under New York State
- 1.4. Regulations Laboratory Analytical Reports by
- 1.5. Building Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

Lancaster High School – 1 Forton Drive, Lancaster, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Transportation Department. Outlets are defined in New York State regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with New York State regulations, Subpart 67 -4: Lead Testing in School Drinking Water, and the Environmental Protection Agency guidance document, "3Ts for Reducing Lead in Drinking Water in Schools", Stohl Environmental's protocol can be summarized as follows:

First-draw samples of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

Laboratory Analysis: Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the New York State Department of Health's Environmental Laboratory Approval Program (E L A P).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw and Confirmatory Samples:

The date of sample event on 10/17/2020 the High School had a total of 238 samples collected. The First draw samples had 213 samples at or below action level of 15 parts per billion and 25 samples above action level of 15 parts per billion.

The date of sample event on 10/17/2020 the William Street School had confirmatory samples at or below action level of 15 parts per billion and above action level of 15 parts per billion that are not applicable.

Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listings of Outlet Requiring Remediation

Locations of Outlets analyzed above New York State level of 15 parts per billion based upon analysis of first draw samples:

Sample Number 169.1-5	Kitchen Center Single Bay	Sink	Laboratory Analysis parts per billion	19.6
Sample Number 169.1-34	Shop Room 168 Center	Sink	Laboratory Analysis parts per billion	36.1
Sample Number 169.1-36	Boys Pool Locker Room	Sink	Laboratory Analysis parts per billion	16.7
Sample Number 169.1-37	Boys Pool Locker Room	D F	Laboratory Analysis parts per billion	30.8
Sample Number 169.1-39	Technology Room 167 Left	Sink	Laboratory Analysis parts per billion	47.0
Sample Number 169.1-42	Technology Room 166 Left	Sink	Laboratory Analysis parts per billion	36.9
Sample Number 169.1-44	Technology Room 166 Right	Sink	Laboratory Analysis parts per billion	15.7
Sample Number 169.1-45	Technology Room 166 Far Right	Bubbler	Laboratory Analysis parts per billion	6.8
Sample Number 169.1-83	Art Room 151 Front Sink Left	Sink	Laboratory Analysis parts per billion	15.3
Sample Number 169.1-111	Credit Union 140	Sink	Laboratory Analysis parts per billion	17.6
Sample Number 169.1-119	Room 138A	Sink	Laboratory Analysis parts per billion	18.9
Sample Number 169.1-120	Room 136A	Sink	Laboratory Analysis parts per billion	24.5
Sample Number 169.1-150	Room 111A Office Area	Sink	Laboratory Analysis parts per billion	52.1
Sample Number 169.1-152	Room 114A	Sink	Laboratory Analysis parts per billion	15.7
Sample Number 169.1-155	S 11 S 12 Prep Room	Sink	Laboratory Analysis parts per billion	48.5
Sample Number 169.1-156	S 13 Hallway	D F	Laboratory Analysis parts per billion	33.8
Sample Number 169.1-157	S 13 S 14 Prep Room	Sink	Laboratory Analysis parts per billion	37.5
Sample Number 169.1-161	Room 128A	Sink	Laboratory Analysis parts per billion	15.3
Sample Number 169.1-171	Room 129 Back	Sink	Laboratory Analysis parts per billion	16.1
Sample Number 169.1-180	Faculty Lavatory 112A Right	Sink	Laboratory Analysis parts per billion	19.1
Sample Number 169.1-182	2nd Floor North Men's Faculty Lavatory Center	Sink	Laboratory Analysis parts per billion	35.5
Sample Number 169.1-183	2nd Floor North Men's Faculty Lavatory Right	Sink	Laboratory Analysis parts per billion	54.4
Sample Number 169.1-184	2nd Floor North Women's Faculty Lavatory Left	Sink	Laboratory Analysis parts per billion	35.5
Sample Number 169.1-223	Room 217 North	Sink	Laboratory Analysis parts per billion	19.9
Sample Number 169.1-228	Room 221	Sink	Laboratory Analysis parts per billion	16.3

1.3 Response Actions Required Under New York State Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the New York State Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building

Environmental Hazards Services, LLC
7469 Whitepine Road
Richmond, VA 23237
Telephone: 800-347-4010

Lead in Drinking Water Analysis Report

Report Number: 20 - 10 - 0 4 8 0 9

Client: Stohl Environmental 3860 California Road Orchard Park, NY 14127

Received Date: 10/22/2020

Reported Date: 11/17/2020

Sampled By: C. Schultz and P. Nichols

Tech Certification Number:

Project Test Address: 2 0 2 0 L-169 .1; Lancaster High School; 1 Forton Drive.; Lancaster, NY

Client Number: 33 - 5 9 8 0

Fax Number: 716-312-8092

Laboratory Results

Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 1

Client Sample Identification: 169.1-1

Collection Date: 10/17/2020

Kitchen 2 Bay Left

Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020

Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 2

Client Sample Identification: 169.1-2

Collection date: 10/17/2020

Kitchen Single Bay

Micrograms per liter: 8.83

Analysis Date: 11/11/2020

Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 3

Client Sample Identification: 169.1-3
Collection date: 10/17/2020
Kitchen Dishwash 3 Bay Left
Micrograms per liter: 3.63
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 4
Client Sample Identification: 169.1-4
Collection date: 10/17/2020
Kitchen Dishwash 3 Bay Right
Micrograms per liter: 5.84
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 5
Client Sample Identification: 169.1-5
Collection date: 10/17/2020
Kitchen Center Single Bay
Micrograms per liter: 19.6
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 6
Client Sample Identification: 169.1-6
Analysis Date: 10/17/2020
Kitchen Kettle
Micrograms per liter: 9.55
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 7
Client Sample Identification: 169.1-7
Collection date: 10/17/2020
Kitchen Steamer
Micrograms per liter: 12.4
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 8
Client Sample Identification: 169.1-8
Collection date: 10/17/2020
Kitchen Staff Lavatory
Micrograms per liter: 1.78
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 0 9
Client Sample Identification: 169.1-9 10/17/2020
Collection Date: 10/17/2020
Kitchen Ice Machine
Micrograms per liter: less than 1.00
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 10
Client Sample Identification: 169.1-10
Collection Date: 10/17/2020
Dish Room Sprayer
Micrograms per liter: less than 1.00
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 11

Client Sample Identification: 169.1-11
Collection Date: 10/17/2020
Dish Room Sink Left
Micrograms per liter: less than 1.00
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 12
Client Sample Identification: 169.1-12
Collection Date: 10/17/2020
Dish Room Sink Right
Micrograms per liter: 6.42
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 13
Client Sample Identification: 169.1-13A
Collection Date: 10/17/2020
Faculty Dining Room
Micrograms per liter: 4.38
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 14
Client Sample Identification: 169.1-13B
Collection Date: 10/17/2020
Faculty Dining Room
Micrograms in liters: 2.68
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 15
Client Sample Identification: 169.1-14
Collection Date: 10/17/2020
Cafeteria Left Fountain
Micrograms in liters: 2.91
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 16
Client Sample Identification: 169.1-15A
Collection Date: 10/17/2020
Cafeteria Right Fountain
Micrograms in liters: 2.74
Analysis Date: 11/11/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 17
Client Sample Identification: 169.1-15B
Collection Date: 10/17/2020
Cafeteria Right Fountain
Micrograms in liters: 3.09
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 18
Client Sample Identification: 169.1-16
Collection Date: 10/17/2020
North Entrance Lobby Left
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 19

Client Sample Identification: 169.1-17A
Collection Date: 10/17/2020
North Entrance Lobby Right
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 20
Client Sample Identification: 169.1-17B
Collection Date: 10/17/2020
North Entrance Lobby Right
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 21
Client Sample Identification: 169.1-18
Collection Date: 10/17/2020
Girls Gym Coach N13 Lavatory
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 22
Client Sample Identification: 169.1-19
Collection Date: 10/17/2020
Girls Gym Locker Room Left
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 23
Client Sample Identification: 169.1-20
Collection Date: 10/17/2020
Girls Gym Locker Room Right
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 24
Client Sample Identification: 169.1-21
Collection Date: 10/17/2020
Girls Gang Lavatory Left
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 25
Client Sample Identification: 169.1-22
Collection Date: 10/17/2020
Girls Gang Lavatory Left Center
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 26
Client Sample Identification: 169.1-23
Collection Date: 10/17/2020
Girls Gang Lavatory Right Center
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 27

Client Sample Identification: 169.1-24
Collection Date: 10/17/2020
Girls Gang Lavatory Right
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 28
Client Sample Identification: 169.1-25
Collection Date: 10/17/2020
Single Lavatory Left of N16
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 29
Client Sample Identification: 169.1-26
Collection Date: 10/17/2020
Boys Gang Lavatory Left
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 30
Client Sample Identification: 169.1-27
Collection Date: 10/17/2020
Boys Gang Lavatory Center
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 31
Client Sample Identification: 169.1-28
Collection Date: 10/17/2020
Boys Gang Lavatory Right
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 32
Client Sample Identification: 169.1-29
Collection Date: 10/17/2020
Boys Gym Locker Room Left
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 33
Client Sample Identification: 169.1-30
Collection Date: 10/17/2020
Boys Gym Locker Room Right
Micrograms in liters: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 34
Client Sample Identification: 169.1-31
Collection Date: 10/17/2020
Boys Gym Coach N18 Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 35

Client Sample Identification: 169.1-32
Collection Date: 10/17/2020
Laundry N19 Handwash
Micrograms per liter: 2.62
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 36
Client Sample Identification: 169.1-33
Collection Date: 10/17/2020
Shop Room 168 Left
Micrograms per liter: 1.98
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 37
Client Sample Identification: 169.1-34
Collection Date: 10/17/2020
Shop Room 168 Center
Micrograms per liter: 36.1
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 38
Client Sample Identification: 169.1-35
Collection Date: 10/17/2020
Shop Room 168 Right
Micrograms per liter: 2.08
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 39
Client Sample Identification: 169.1-36
Collection Date: 10/17/2020
Boys Pool Locker Room
Micrograms per liter: 16.7
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 40
Client Sample Identification: 169.1-37
Collection Date: 10/17/2020
Boys Pool Locker Room
Micrograms per liter: 30.8
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 41
Client Sample Identification: 169.1-38
Collection Date: 10/17/2020
Boys Vestibule Lavatory
Micrograms per liter: 7.34
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 42
Client Sample Identification: 169.1-39
Collection Date: 10/17/2020
Technology Room 167 Left
Micrograms per liter: 47.0
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 43

Client Sample Identification: 169.1-40
Collection Date: 10/17/2020
Technology Room 167 Center
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 44
Client Sample Identification: 169.1-41
Collection Date: 10/17/2020
Technology Room 167 Right
Micrograms per liter: 3.14
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 45
Client Sample Identification: 169.1-42
Collection Date: 10/17/2020
Technology Room 166 Left
Micrograms per liter: 36.9
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 46
Client Sample Identification: 169.1-43
Collection Date: 10/17/2020
Technology Room 166 Center
Micrograms per liter: 10.2
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 47
Client Sample Identification: 169.1-44
Collection Date: 10/17/2020
Technology Room 166 Right
Micrograms per liter: 15.7
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 48
Client Sample Identification: 169.1-45
Collection Date: 10/17/2020
Technology Room 166 Far Right
Micrograms per liter: 26.8
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 49
Client Sample Identification: 169.1-46
Collection Date: 10/17/2020
Pool 166 Hallway
Micrograms per liter: 1.74
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 50
Client Sample Identification: 169.1-47
Collection Date: 10/17/2020
Field House Hallway Lavatory
Micrograms per liter: 4.08
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 51

Client Sample Identification: 169.1-49
Collection Date: 10/17/2020
Shop Room 153 Center
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 52
Client Sample Identification: 169.1-50
Collection Date: 10/17/2020
Shop Room 153 Right
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 53
Client Sample Identification: 169.1-51
Collection Date: 10/17/2020
Art Room 151
Micrograms per liter: 8.14
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 54
Client Sample Identification: 169.1-52
Collection Date: 10/17/2020
Boys Field house Locker 1 Left
Micrograms per liter: 9.55
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 55
Client Sample Identification: 169.1-53
Collection Date: 10/17/2020
Boys Field house Locker 1 Left Center
Micrograms per liter: 5.39
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 56
Client Sample Identification: 169.1-54
Collection Date: 10/17/2020
Boys Field house Locker 1 Right Center
Micrograms per liter: 5.43
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 57
Client Sample Identification: 169.1-55
Collection Date: 10/17/2020
Boys Field house Locker 1 Right
Micrograms per liter: 5.22
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 58
Client Sample Identification: 169.1-56
Collection Date: 10/17/2020
Girls Field house Locker 1 Left
Micrograms per liter: 9.95
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 59

Client Sample Identification: 169.1-57
Collection Date: 10/17/2020
Girls Field house Locker 1 Left Center
Micrograms per liter: 4.11
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 60
Client Sample Identification: 169.1-58
Collection Date: 10/17/2020
Girls Field house Locker 1 Right Center
Micrograms per liter: 5.10
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 61
Client Sample Identification: 169.1-59
Collection Date: 10/17/2020
Girls Field house Locker 1 Right
Micrograms per liter: 3.06
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 62
Client Sample Identification: 169.1-60
Collection Date: 10/17/2020
Boys Field house Locker 2 Left
Micrograms per liter: 3.89
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 63
Client Sample Identification: 169.1-61
Collection Date: 10/17/2020
Boys Field house Locker 2 Left Center
Micrograms per liter: 3.84
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 64
Client Sample Identification: 169.1-62
Collection Date: 10/17/2020
Boys Field house Locker 2 Right Center
Micrograms per liter: 2.53
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 65
Client Sample Identification: 169.1-63
Collection Date: 10/17/2020
Boys Field house Locker 2 Right
Micrograms per liter: 5.46
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 66
Client Sample Identification: 169.1-64
Collection Date: 10/17/2020
Girls Field house Locker 2 Left
Micrograms per liter: 4.33
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 67

Client Sample Identification: 169.1-65
Collection Date: 10/17/2020
Girls Field house Locker 2 Left Center
Micrograms per liter: 1.70
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 68
Client Sample Identification: 169.1-66
Collection Date: 10/17/2020
Girls Field house Locker 2 Right Center
Micrograms per liter: 2.12
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 69
Client Sample Identification: 169.1-67
Collection Date: 10/17/2020
Girls Field house Locker 2 Right
Micrograms per liter: 3.98
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 70
Client Sample Identification: 169.1-68
Collection Date: 10/17/2020
Trainer's Room 157 Ice
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 71
Client Sample Identification: 169.1-69
Collection Date: 10/17/2020
Trainer's Room 157
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 72
Client Sample Identification: 169.1-70
Collection Date: 10/17/2020
Girls Coach's Office 159
Micrograms per liter: 3.55
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9- 073
Client Sample Identification: 169.1-71
Collection Date: 10/17/2020
Boys Coach's Office 160
Micrograms per liter: 1.66
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 74
Client Sample Identification: 169.1-72A
Collection Date: 10/17/2020
Field House Fountain Left
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 75

Client Sample Identification: 169.1-72B
Collection Date: 10/17/2020
Field House Fountain Left
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 76
Client Sample Identification: 169.1-73A
Collection Date: 10/17/2020
Field House Fountain Right
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 77
Client Sample Identification: 169.1-73B
Collection Date: 10/17/2020
Field House Fountain Right
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 78
Client Sample Identification: 169.1-74
Collection Date: 10/17/2020
Field House Men's Lavatory Left
Micrograms per liter: 3.54
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 79
Client Sample Identification: 169.1-75
Collection Date: 10/17/2020
Field house Men's Lavatory Left Center
Micrograms per liter: 2.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 80
Client Sample Identification: 169.1-76
Collection Date: 10/17/2020
Field house Men's Lavatory Right Center
Micrograms per liter: 2.93
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 81
Client Sample Identification: 169.1-77
Collection Date: 10/17/2020
Field house Men's Lavatory Right
Micrograms per liter: 2.73
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 82
Client Sample Identification: 169.1-78
Collection Date: 10/17/2020
Field house Women's Lavatory Left
Micrograms per liter: 13.1
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 83

Client Sample Identification: 169.1-78
Collection Date: 10/17/2020
Field house Women's Lavatory Left Center
Micrograms per liter: 4.92
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 84
Client Sample Identification: 169.1-80
Collection Date: 10/17/2020
Field house Women's Lavatory Right Center
Micrograms per liter: 4.51
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 85
Client Sample Identification: 169.1-81
Collection Date: 10/17/2020
Field house Women's Lavatory Right
Micrograms per liter: 5.52
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 86
Client Sample Identification: 169.1-82
Collection Date: 10/17/2020
Music Room 174.4
Micrograms per liter: 1.05
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 87
Client Sample Identification: 169.1-83
Collection Date: 10/17/2020
Art Room 151 Front Sink Left
Micrograms per liter: 15.3
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 88
Client Sample Identification: 169.1-84
Collection Date: 10/17/2020
Art Room 151 Front Sink Center
Micrograms per liter: 3.96
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 89
Client Sample Identification: 169.1-85
Collection Date: 10/17/2020
Art Room 151 Front Sink Right
Micrograms per liter: 12.0
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 90
Client Sample Identification: 169.1-86
Collection Date: 10/17/2020
Art Room 151 Back Sink Left
Micrograms per liter: 6.93
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 91

Client Sample Identification: 169.1-87
Collection Date: 10/17/2020
Art Room 151 Back Sink Center
Micrograms per liter: 2.02
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 92
Client Sample Identification: 169.1-88
Collection Date: 10/17/2020
Art Room 151 Back Sink Right
Micrograms per liter: 11.9
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 93
Client Sample Identification: 169.1-89
Collection Date: 10/17/2020
Art Room 150 Front Sink Left
Micrograms per liter: 4.89
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 94
Client Sample Identification: 169.1-90
Collection Date: 10/17/2020
Art Room 150 Front Sink Center
Micrograms per liter: 6.09
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 95
Client Sample Identification: 169.1-91
Collection Date: 10/17/2020
Art Room 150 Front Sink Right
Micrograms per liter: 4.15
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 96
Client Sample Identification: 169.1-92
Collection Date: 10/17/2020
Art Room 150 Back Sink Left
Micrograms per liter: 2.31
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 97
Client Sample Identification: 169.1-93
Collection Date: 10/17/2020
Art Room 150 Back Sink Center
Micrograms per liter: 1.55
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 98
Client Sample Identification: 169.1-94
Collection Date: 10/17/2020
Art Room 150 Back Sink Right
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-0 99

Client Sample Identification: 169.1-95A
Collection Date: 10/17/2020
Art Room 150 Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-100
Client Sample Identification: 169.1-95B
Collection Date: 10/17/2020
Art Room 150 Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-101
Client Sample Identification: 169.1-96
Collection Date: 10/17/2020
Stage Room 174.3
Micrograms per liter: 2.95
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-102
Client Sample Identification: 169.1-97
Collection Date: 10/17/2020
Art Room 149 Left
Micrograms per liter: 12.2
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-103
Client Sample Identification: 169.1-98
Collection Date: 10/17/2020
Art Room 149 Left Center
Micrograms per liter: 3.27
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-104
Client Sample Identification: 169.1-99
Collection Date: 10/17/2020
Art Room 149 Right Center
Micrograms per liter: 2.25
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-105
Client Sample Identification: 169.1-100
Collection Date: 10/17/2020
Art Room 149 Right
Micrograms per liter: 13.4
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-106
Client Sample Identification: 169.1-101
Collection Date: 10/17/2020
Art Room 147 Hallway
Micrograms per liter: 3.91
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-107

Client Sample Identification: 169.1-102
Collection Date: 10/17/2020
Art Room 147 Left
Micrograms per liter: 14.4
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-108
Client Sample Identification: 169.1-103
Collection Date: 10/17/2020
Art Room 147 Right
Micrograms per liter: 5.94
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-109
Client Sample Identification: 169.1-104
Collection Date: 10/17/2020
Room 146
Micrograms per liter: 11.3
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-110
Client Sample Identification: 169.1-105
Collection Date: 10/17/2020
Room 145
Micrograms per liter: 2.06
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-111
Client Sample Identification: 169.1-106
Collection Date: 10/17/2020
Room 143b
Micrograms per liter: 3.48
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-112
Client Sample Identification: 169.1-107
Collection Date: 10/17/2020
Room 143 Hallway
Micrograms per liter: 3.58
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-113
Client Sample Identification: 169.1-108
Collection Date: 10/17/2020
143 Hall Women's Faculty Left
Micrograms per liter: 7.36
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-114
Client Sample Identification: 169.1-109
Collection Date: 10/17/2020
143 Hall Women's Faculty Right
Micrograms per liter: 5.26
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-115

Client Sample Identification: 169.1-110
Collection Date: 10/17/2020
143 Hallway Men's Faculty Left
Micrograms per liter: 5.63
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-116
Client Sample Identification: 169.1-111
Collection Date: 10/17/2020
Credit Union 140
Micrograms per liter: 17.6
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-117
Client Sample Identification: 169.1-112
Collection Date: 10/17/2020
Boys Lavatory B7
Micrograms per liter: 1.76
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-118
Client Sample Identification: 169.1-113
Collection Date: 10/17/2020
Room 138 Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-119
Client Sample Identification: 169.1-114
Collection Date: 10/17/2020
Girls Lavatory G7 Left
Micrograms per liter: 9.82
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-120
Client Sample Identification: 169.1-115
Collection Date: 10/17/2020
Girls Lavatory G7 Center
Micrograms per liter: 5.12
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-121
Client Sample Identification: 169.1-116
Collection Date: 10/17/2020
Girls Lavatory G7 Right
Micrograms per liter: 2.63
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-122
Client Sample Identification: 169.1-117
Collection Date: 10/17/2020
Room 141 Left
Micrograms per liter: 5.69
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-123

Client Sample Identification: 169.1-118
Collection Date: 10/17/2020
Room 141 Right
Micrograms per liter: 2.56
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-124
Client Sample Identification: 169.1-119
Collection Date: 10/17/2020
Room 138A
Micrograms per liter: 18.9
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-125
Client Sample Identification: 169.1-120
Collection Date: 10/17/2020
Room 136A
Micrograms per liter: 24.5
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-126
Client Sample Identification: 169.1-121
Collection Date: 10/17/2020
Room 133 Hallway
Micrograms per liter: 2.33
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-127
Client Sample Identification: 169.1-122
Collection Date: 10/17/2020
Fitness Center 163
Micrograms per liter: 1.08
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-128
Client Sample Identification: 169.1-123
Collection Date: 10/17/2020
Fitness Center Pool Hallway
Micrograms per liter: 14.4
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-129
Client Sample Identification: 169.1-124
Collection Date: 10/17/2020
Girls Pool Locker Room
Micrograms per liter: 11.8
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-130
Client Sample Identification: 169.1-125
Collection Date: 10/17/2020
Girls Pool Locker Room
Micrograms per liter: 11.6
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-131

Client Sample Identification: 169.1-126
Collection Date: 10/17/2020
Girls Pool Vestibule
Micrograms per liter: 3.41
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-132
Client Sample Identification: 169.1-127A
Collection Date: 10/17/2020
Room 174 Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-133
Client Sample Identification: 169.1-127B
Collection Date: 10/17/2020
Room 174 Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-134
Client Sample Identification: 169.1-128
Collection Date: 10/17/2020
Accessible Lavatory
Micrograms per liter: 5.87
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-135
Client Sample Identification: 169.1-129
Collection Date: 10/17/2020
Men's Main Office Front Left
Micrograms per liter: 2.14
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-136
Client Sample Identification: 169.1-130
Collection Date: 10/17/2020
Men's Main office Back Left
Micrograms per liter: 5.98
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-137
Client Sample Identification: 169.1-131
Collection Date: 10/17/2020
Men's Main office Back Right
Micrograms per liter: 3.98
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-138
Client Sample Identification: 169.1-132
Collection Date: 10/17/2020
Men's Main office Front Right
Micrograms per liter: 1.68
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-139

Client Sample Identification: 169.1-133
Collection Date: 10/17/2020
Women's Main Office Left
Micrograms per liter: 3.54
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-140
Client Sample Identification: 169.1-134
Collection Date: 10/17/2020
Women's Main Office Center
Micrograms per liter: 1.16
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-141
Client Sample Identification: 169.1-135
Collection Date: 10/17/2020
Women's Main Office Right
Micrograms per liter: 1.07
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-142
Client Sample Identification: 169.1-136
Collection Date: 10/17/2020
Principal's Office Lavatory
Micrograms per liter: 3.11
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-143
Client Sample Identification: 169.1-137
Collection Date: 10/17/2020
Main Office Lavatory
Micrograms per liter: 2.48
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-144
Client Sample Identification: 169.1-138A
Collection Date: 10/17/2020
Main Office Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-145
Client Sample Identification: 169.1-138B
Collection Date: 10/17/2020
Main Office Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-146
Client Sample Identification: 169.1-139
Collection Date: 10/17/2020
Room 184 Lounge
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-147

Client Sample Identification: 169.1-140
Collection Date: 10/17/2020
Nurse Office Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-148
Client Sample Identification: 169.1-141
Collection Date: 10/17/2020
Nurse Office Kitchen
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-149
Client Sample Identification: 169.1-142
Collection Date: 10/17/2020
Room 102 Hallway Lavatory
Micrograms per liter: 3.65
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-150
Client Sample Identification: 169.1-143
Collection Date: 10/17/2020
Room 105 Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-151
Client Sample Identification: 169.1-144
Collection Date: 10/17/2020
Ladies Lavatory G3 Left
Micrograms per liter: 7.36
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-152
Client Sample Identification: 169.1-145
Collection Date: 10/17/2020
Ladies Lavatory G3 Center
Micrograms per liter: 9.32
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-153
Client Sample Identification: 169.1-146
Collection Date: 10/17/2020
Ladies Lavatory G3 Right
Micrograms per liter: 2.77
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-154
Client Sample Identification: 169.1-147
Collection Date: 10/17/2020
Men's Lavatory B3 Left
Micrograms per liter: 3.88
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-155

Client Sample Identification: 169.1-148
Collection Date: 10/17/2020
Men's Lavatory B3 Center
Micrograms per liter: 2.92
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-156
Client Sample Identification: 169.1-149
Collection Date: 10/17/2020
Men's Lavatory B3 Right
Micrograms per liter: 2.52
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-157
Client Sample Identification: 169.1-150
Collection Date: 10/17/2020
Room 111A Office Area
Micrograms per liter: 52.1
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-158
Client Sample Identification: 169.1-151
Collection Date: 10/17/2020
Room 114
Micrograms per liter: 14.3
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-159
Client Sample Identification:
Collection Date: 10/17/2020
Room 114A
Micrograms per liter: 15.7
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-160
Client Sample Identification: 169.1-153
Collection Date: 10/17/2020
Room 116 Hallway
Micrograms per liter: 1.06
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-161
Client Sample Identification: 169.1-154
Collection Date: 10/17/2020
Room 116
Micrograms per liter: 10.4
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-162
Client Sample Identification: 169.1-155
Collection Date: 10/17/2020
S11 S12 Prep Room
Micrograms per liter: 48.5
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-163

Client Sample Identification: 169.1-156
Collection Date: 10/17/2020
S13 Hallway
Micrograms per liter: 33.8
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-164
Client Sample Identification: 169.1-157
Collection Date: 10/17/2020
S13 S14 Prep Room
Micrograms per liter: 37.5
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-165
Client Sample Identification: 169.1-158
Collection Date: 10/17/2020
S15 S16 Prep Room
Micrograms per liter: 14.4
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-166
Client Sample Identification: 169.1-159
Collection Date: 10/17/2020
Room 124
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-167
Client Sample Identification: 169.1-160
Collection Date: 10/17/2020
Room 125 Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-168
Client Sample Identification: 169.1-161
Collection Date: 10/17/2020
Room 128a
Micrograms per liter: 15.3
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-169
Client Sample Identification: 169.1-162
Collection Date: 10/17/2020
Boys Lavatory B5 Left
Micrograms per liter: 8.37
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-170
Client Sample Identification: 169.1-163
Collection Date: 10/17/2020
Boys Lavatory B5 Right
Micrograms per liter: 7.13
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-171

Client Sample Identification: 169.1-164
Collection Date: 10/17/2020
Girls Lavatory G5 Left
Micrograms per liter: 8.66
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-172
Client Sample Identification: 169.1-165
Collection Date: 10/17/2020
Girls Lavatory G5 Center
Micrograms per liter: 5.45
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-173
Client Sample Identification: 169.1-166
Collection Date: 10/17/2020
Girls Lavatory G5 Right
Micrograms per liter: 10.5
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-174
Client Sample Identification: 169.1-167
Collection Date: 10/17/2020
Room 128 Front
Micrograms per liter: 14.2
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-175
Client Sample Identification: 169.1-168
Collection Date: 10/17/2020
Room 128 Back
Micrograms per liter: 3.93
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-176
Client Sample Identification: 169.1-169
Collection Date: 10/17/2020
Room 130A
Micrograms per liter: 9.27
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-177
Client Sample Identification: 169.1-170
Collection Date: 10/17/2020
Room 129 Front
Micrograms per liter: 2.70
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-178
Client Sample Identification: 169.1-171
Collection Date: 10/17/2020
Room 129 Back
Micrograms per liter: 16.1
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-179

Client Sample Identification: 169.1-172
Collection Date: 10/17/2020
Room 131A
Micrograms per liter: 11.2
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-180
Client Sample Identification: 169.1-173
Collection Date: 10/17/2020
Room 130 Front
Micrograms per liter: 3.95
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-181
Client Sample Identification: 169.1-174
Collection Date: 10/17/2020
Room 130 North Wall Center
Micrograms per liter: 10.3
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-182
Client Sample Identification: 169.1-175
Collection Date: 10/17/2020
Room 131 Front
Micrograms per liter: 5.17
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-183
Client Sample Identification: 169.1-176
Collection Date: 10/17/2020
Room 131 Back
Micrograms per liter: 7.91
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-184
Client Sample Identification: 169.1-177
Collection Date: 10/17/2020
Faculty Lavatory 112B Left
Micrograms per liter: 3.56
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-04 8 0 9-185
Client Sample Identification: 169.1-178
Collection Date: 10/17/2020
Faculty Lavatory 112B Right
Micrograms per liter: 2.90
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-186
Client Sample Identification: 169.1-179
Collection Date: 10/17/2020
Faculty Lavatory 112A Left
Micrograms per liter: 12.6
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-187

Client Sample Identification: 169.1-180
Collection Date: 10/17/2020
Faculty Lavatory 112A Right
Micrograms per liter: 19.1
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-188
Client Sample Identification: 169.1-181
Collection Date: 10/17/2020
Second Floor North Men's Faculty Left
Micrograms per liter: 14.8
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-189
Client Sample Identification: 169.1-182
Collection Date: 10/17/2020
Second Floor North Men's Faculty Center
Micrograms per liter: 35.5
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-190
Client Sample Identification: 169.1-183
Collection Date: 10/17/2020
Second Floor North Men's Faculty Right
Micrograms per liter: 54.4
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-191
Client Sample Identification: 169.1-184
Collection Date: 10/17/2020
Second Floor North Women's Faculty Left
Micrograms per liter: 35.5
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-192
Client Sample Identification: 169.1-185
Collection Date: 10/17/2020
Second Floor North Women's Faculty Left Center
Micrograms per liter: 12.0
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-193
Client Sample Identification: 169.1-186
Collection Date: 10/17/2020
Second Floor North Women's Faculty Right Center
Micrograms per liter: 5.99
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-194
Client Sample Identification: 169.1-187
Collection Date: 10/17/2020
Second Floor North Women's Faculty Right
Micrograms per liter: 3.11
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-195

Client Sample Identification: 169.1-188
Collection Date: 10/17/2020
Room 200.10
Micrograms per liter: 6.81
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-196
Client Sample Identification: 169.1-189
Collection Date: 10/17/2020
Room 200.10 Hallway
Micrograms per liter: 2.32
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-197
Client Sample Identification: 169.1-190
Collection Date: 10/17/2020
Room 207 Hallway
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-198
Client Sample Identification: 169.1-191
Collection Date: 10/17/2020
Girls Lavatory G4 Left
Micrograms per liter: 6.27
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-199
Client Sample Identification: 169.1-192
Collection Date: 10/17/2020
Girls Lavatory G4 Center
Micrograms per liter: 2.21
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-200
Client Sample Identification: 169.1-193
Collection Date: 10/17/2020
Girls Lavatory G4 Right
Micrograms per liter: 3.07
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-201
Client Sample Identification: 169.1-194
Collection Date: 10/17/2020
Boys Lavatory B4 Left
Micrograms per liter: 4.42
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-202
Client Sample Identification: 169.1-195
Collection Date: 10/17/2020
Boys Lavatory B4 Center
Micrograms per liter: 3.51
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-203

Client Sample Identification: 169.1-196
Collection Date: 10/17/2020
Boys Lavatory B4 Right
Micrograms per liter: 6.40
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-204
Client Sample Identification: 169.1-197
Collection Date: 10/17/2020
Room 210
Micrograms per liter: 6.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-205
Client Sample Identification: 169.1-199
Collection Date: 10/17/2020
Faculty Room 243 Ladies Lavatory
Micrograms per liter: 2.95
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-206
Client Sample Identification: 169.1-200
Collection Date: 10/17/2020
Faculty Room 243 Men's Lavatory
Micrograms per liter: 4.28
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-207
Client Sample Identification: 169.1-201
Collection Date: 10/17/2020
Faculty Room 243 Kitchenette
Micrograms per liter: 1.17
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-208
Client Sample Identification: 169.1-202
Collection Date: 10/17/2020
Boys Lavatory B8 Left
Micrograms per liter: 4.47
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-209
Client Sample Identification: 169.1-203
Collection Date: 10/17/2020
Boys Lavatory B8 Center
Micrograms per liter: 3.14
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-210
Client Sample Identification: 169.1-204
Collection Date: 10/17/2020
Boys Lavatory B8 Right
Micrograms per liter: 1.51
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-211

Client Sample Identification: 169.1-205
Collection Date: 10/17/2020
Between Lavatories B8 And G8
Micrograms per liter: 1.20
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-212
Client Sample Identification: 169.1-206
Collection Date: 10/17/2020
Girls Lavatory G8 Left
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-213
Client Sample Identification: 169.1-207
Collection Date: 10/17/2020
Girls Lavatory G8 Center
Micrograms per liter: 4.77
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-214
Client Sample Identification: 169.1-208
Collection Date: 10/17/2020
Girls Lavatory G8 Right
Micrograms per liter: 6.29
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-215
Client Sample Identification: 169.1-209
Collection Date: 10/17/2020
Room 233 Hallway
Micrograms per liter: 2.49
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-216
Client Sample Identification: 169.1-210
Collection Date: 10/17/2020
Room 227 Hallway
Micrograms per liter: 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-217
Client Sample Identification: 169.1-211
Collection Date: 10/17/2020
Girls Lavatory G6 Left
Micrograms per liter: 5.84
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-218
Client Sample Identification: 169.1-212
Collection Date: 10/17/2020
Girls Lavatory G6 Center
Micrograms per liter: 1.61
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-219

Client Sample Identification: 169.1-213
Collection Date: 10/17/2020
Girls Lavatory G6 Right
Micrograms per liter: 2.01
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-220
Client Sample Identification: 169.1-214
Collection Date: 10/17/2020
Boys Lavatory B6 Left
Micrograms per liter: 2.24
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-221
Client Sample Identification: 169.1-215
Collection Date: 10/17/2020
Boys Lavatory B6 Right
Micrograms per liter: 3.09
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-222
Client Sample Identification: 169.1-216
Collection Date: 10/17/2020
Boys South Lavatory Left
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-223
Client Sample Identification: 169.1-217
Collection Date: 10/17/2020
Boys South Lavatory Right
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-224
Client Sample Identification: 169.1-218
Collection Date: 10/17/2020
South End Lobby Left
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-225
Client Sample Identification: 169.1-219
Collection Date: 10/17/2020
South End Lobby Right
Micrograms per liter: less than 1.00
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-226
Client Sample Identification: 169.1-220
Collection Date: 10/17/2020
Girls South Lavatory Left
Micrograms per liter: 1.56
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-227

Client Sample Identification: 169.1-221
Collection Date: 10/17/2020
Girls South Lavatory Right
Micrograms per liter: 1.71
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-228
Client Sample Identification: 169.1-222
Collection Date: 10/17/2020
Room 216
Micrograms per liter: 8.62
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-229
Client Sample Identification: 169.1-223
Collection Date: 10/17/2020
Room 217 North
Micrograms per liter: 19.9
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-230
Client Sample Identification: 169.1-224
Collection Date: 10/17/2020
Room 217 South
Micrograms per liter: 6.40
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-231
Client Sample Identification: 169.1-225
Collection Date: 10/17/2020
Room 217 Southwest
Micrograms per liter: 12.5
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-232
Client Sample Identification: 169.1-226
Collection Date: 10/17/2020
Room 217 Northwest
Micrograms per liter: 10.8
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-233
Client Sample Identification: 169.1-228
Collection Date: 10/17/2020
Room 221.2
Micrograms per liter: 16.3
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-234
Client Sample Identification: 169.1-229
Collection Date: 10/17/2020
Media Center 245.2
Micrograms per liter: 2.76
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-235

Client Sample Identification: 169.1-230
Collection Date: 10/17/2020
Basement Rifle Range Hallway
Micrograms per liter: 5.68
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-236
Client Sample Identification: 169.1-231
Collection Date: 10/17/2020
Basement Rifle Range Hallway
Micrograms per liter: 5.03
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-237
Client Sample Identification: 169.1-232
Collection Date: 10/17/2020
Basement Laundry Room
Micrograms per liter: 5.43
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 4 8 0 9-238
Client Sample Identification: 169.1-233
Collection Date: 10/17/2020
Basement Staff Lavatory
Micrograms per liter: 9.10
Analysis Date: 11/13/2020

Method: SM 3 1 1 3 B – 2 0 1 0

Analyst: Jennalee Hertzler

Accreditation Number: New York 1 1 7 1 4

Reviewed and Authorized Signatory by Melissa Kanode; Quality Assurance Quality Control Clerk

Sample results denoted with a "less than" sign contain less than the reporting limit which is 1 part per billion.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 parts per billion. The results herein conform to National Environmental Laboratory Accreditation Conference standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

1.5 Laboratory Certifications

New York State Department of Health Wadsworth Center

Certificate of Approval for Laboratory Service

issued in accordance with and pursuant to section 502 Public Health Law of New York state

Expires 12:01 AM April 01, 2021

Issued April 01, 2020

New York Laboratory Identification Number: 1 1 7 1 4

Ms. Julie Dickerson

Environmental Hazards Services, L.L.C.

7469 Whitepine Road

North Chesterfield, VA 23237

is hereby approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category Environmental Analyses Potable Water.

All approved analytes are listed below:

Metals 1

Copper, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Lead, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Serial Number: 6 1 5 1 4

Property of the New York State Department of Health. Certificates are valid only at the address shown; must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518)485-5570 to verify the laboratory's accreditation status.

1.6 Chains of Custody

Chain of Custody Document submitted to Environmental Hazards Services, L.L.C.

Stohl Job Number: 2 0 2 0 L -169 .1

Lancaster Central School District

Contact: Michael Bryniarski

Lancaster High School

1 Forton Drive, Lancaster, New York

Lead: Water by S M 19, 21-23 3 1 1 3 B (-04, -10)

Turnaround 20 days

Sample Number	169.1-1	Kitchen 2 Bay Left	Outlet Type	Sink	8:00
Sample Number	169.1-2	Kitchen Single Bay	Outlet Type	Sink	8:01
Sample Number	169.1-3	Kitchen Dishwash 3 Bay Left	Outlet Type	Sink	8:02
Sample Number	169.1-4	Kitchen Dishwash 3 Bay Right	Outlet Type	Sink	8:03
Sample Number	169.1-5	Kitchen Center Single Bay	Outlet Type	Sink	8:04
Sample Number	169.1-6	Kitchen Kettle	Outlet Type	Sink	8:05
Sample Number	169.1-7	Kitchen Steamer	Outlet Type	Sink	8:06
Sample Number	169.1-8	Kitchen Staff Lavatory	Outlet Type	Sink	8:07
Sample Number	169.1-9	Kitchen Ice Machine	Outlet Type	I M	8:08
Sample Number	169.1-10	Dish Room Sprayer	Outlet Type	Sink	8:09
Sample Number	169.1-11	Dish Room Sink Left	Outlet Type	Sink	8:10

Sample Number	169.1-12	Dish Room Sink Right	Outlet Type	Sink	8:11
Sample Number	169.1-13A	Faculty Dining Room	Outlet Type	D F A	8:12
Sample Number	169.1-13B	Faculty Dining Room	Outlet Type	D F B	8:13
Sample Number	169.1-14	Cafeteria Left Fountain	Outlet Type	D F A	8:14
Sample Number	169.1-15A	Cafeteria Right Fountain	Outlet Type	D F A	8:15
Sample Number	169.1-15B	Cafeteria Right Fountain	Outlet Type	D F B	8:16
Sample Number	169.1-16	North Entrance Lobby Left	Outlet Type	D F A	8:17
Sample Number	169.1-17A	North Entrance Lobby Right	Outlet Type	D F A	8:18
Sample Number	169.1-17B	North Entrance Lobby Right	Outlet Type	D F B	8:19
Sample Number	169.1-18	Girl's Gym Coach N13 Lavatory	Outlet Type	Sink	8:20
Sample Number	169.1-19	Girls Gym Locker Room Left	Outlet Type	Sink	8:21
Sample Number	169.1-20	Girls Gym Locker Room Right	Outlet Type	Sink	8:22
Sample Number	169.1-21	Girls Gang Lavatory Left	Outlet Type	Sink	8:23
Sample Number	169.1-22	Girls Gang Lavatory Left Center	Outlet Type	Sink	8:24
Sample Number	169.1-23	Girls Gang Lavatory Right Center	Outlet Type	Sink	8:25
Sample Number	169.1-24	Girls Gang Lavatory Right	Outlet Type	Sink	8:26
Sample Number	169.1-25	Single Lavatory Left of N16	Outlet Type	Sink	8:27
Sample Number	169.1-26	Boys Gang Lavatory Left	Outlet Type	Sink	8:28
Sample Number	169.1-27	Boys Gang Lavatory Center	Outlet Type	Sink	8:29
Sample Number	169.1-28	Boys Gang Lavatory Right	Outlet Type	Sink	8:30
Sample Number	169.1-29	Boys Gym Locker Room Left	Outlet Type	Sink	8:31
Sample Number	169.1-30	Boys Gym Locker Room Right	Outlet Type	Sink	8:32
Sample Number	169.1-31	Boys Gym Coach N18 Lavatory	Outlet Type	Sink	8:33
Sample Number	169.1-32	Laundry N19 Handwash	Outlet Type	Sink	8:34
Sample Number	169.1-33	Shop Room 168 Left	Outlet Type	Sink	8:35
Sample Number	169.1-34	Shop Room 168 Center •	Outlet Type	Sink	8:36
Sample Number	169.1-35	Shop Room 168 Right •	Outlet Type	Sink	8:37
Sample Number	169.1-36	Boys Pool Locker Room	Outlet Type	Sink	8:38
Sample Number	169.1-37	Boys Pool Locker Room	Outlet Type	D F A	8:39
Sample Number	169.1-38	Boys Vestibule Lavatory	Outlet Type	Sink	8:40
Sample Number	169.1-39	Technology Room 167 Left	Outlet Type	Sink	8:41
Sample Number	169.1-40	Technology Room 167 Center	Outlet Type	Sink	8:42
Sample Number	169.1-41	Technology Room 167 Right	Outlet Type	Sink	8:43
Sample Number	169.1-42	Technology Room 166 Left	Outlet Type	Sink	8:44
Sample Number	169.1-43	Technology Room 166 center	Outlet Type	Sink	8:45
Sample Number	169.1-44	Technology Room 166 Right	Outlet Type	Sink	8:46
Sample Number	169.1-45	Technology Room 166 Far Right	Outlet Type	Bubbler	8:47
Sample Number	169.1-46	Pool 166 Hallway	Outlet Type	D F A	8:48
Sample Number	169.1-47	Field House Hallway Lavatory	Outlet Type	Sink	8:49
Sample Number	169.1-49	Shop Room 153 Center	Outlet Type	Sink	8:50
Sample Number	169.1-50	Shop Room 153 Right	Outlet Type	Sink	8:51
Sample Number	169.1-51	Art Room 151	Outlet Type	Sink	8:52
Sample Number	169.1-52	Boys Field House Locker 1 Left	Outlet Type	Sink	8:53
Sample Number	169.1-53	Boy Field House Locker 1 Left Center	Outlet Type	Sink	8:54
Sample Number	169.1-54	Boys Field House Locker 1 Right Center	Outlet Type	Sink	8:55
Sample Number	169.1-55	Boys Field House Locker 1 Right	Outlet Type	Sink	8:56
Sample Number	169.1-56	Girls Field House Locker 1 Left	Outlet Type	Sink	8:57
Sample Number	169.1-57	Girls Field House Locker 1 Left Center	Outlet Type	Sink	8:58
Sample Number	169.1-58	Girls Field House Locker 1 Right Center	Outlet Type	Sink	8:59
Sample Number	169.1-59	Girls Field House Locker 1 Right	Outlet Type	Sink	9:00
Sample Number	169.1-60	Boys Field House Locker 2 Left	Outlet Type	Sink	9:01
Sample Number	169.1-61	Boys Field House Locker 2 Left Center	Outlet Type	Sink	9:02
Sample Number	169.1-62	Boys Field House Locker 2 Right Center	Outlet Type	Sink	9:03
Sample Number	169.1-63	Boys Field House Locker 2 Right	Outlet Type	Sink	9:04
Sample Number	169.1-64	Girls Field House Locker 2 Left	Outlet Type	Sink	9:05
Sample Number	169.1-65	Girls Field House Locker 2 Left Center	Outlet Type	Sink	9:06
Sample Number	169.1-66	Girls Field House Locker 2 Right Center	Outlet Type	Sink	9:07
Sample Number	169.1-67	Girls Field House Locker 2 Right	Outlet Type	Sink	9:08

Sample Number	169.1-68	Trainer's Room 157 Ice	Outlet Type	I M	9:09
Sample Number	169.1-69	Trainer's Room 157	Outlet Type	Sink	9:10
Sample Number	169.1-70	Girls Coach's Office 159	Outlet Type	Sink	9:11
Sample Number	169.1-71	Boys Coach's Office 160	Outlet Type	Sink	9:12
Sample Number	169.1-72A	Field House Fountain Left	Outlet Type	D F A	9:13
Sample Number	169.1-72B	Field House Fountain Left	Outlet Type	D F B	9:14
Sample Number	169.1-73A	Field House Fountain Right	Outlet Type	D F A	9:15
Sample Number	169.1-73B	Field House Fountain Right	Outlet Type	D F B	9:16
Sample Number	169.1-74	Field House Men's Lavatory Left	Outlet Type	Sink	9:17
Sample Number	169.1-75	Field House Men's Lavatory Left Center	Outlet Type	Sink	9:18
Sample Number	169.1-76	Field House Men's Lavatory Right Center	Outlet Type	Sink	9:19
Sample Number	169.1-77	Field House Men's Lavatory Right	Outlet Type	Sink	9:20
Sample Number	169.1-78	Field House Women's Lavatory Left	Outlet Type	Sink	9:21
Sample Number	169.1-79	Field House Women's Lavatory Left Center	Outlet Type	Sink	9:22
Sample Number	169.1-80	Field House Women's Lavatory Right Center	Outlet Type	Sink	9:23
Sample Number	169.1-81	Field House Women's Lavatory Right	Outlet Type	Sink	9:24
Sample Number	169.1-82	Music Room 174.4	Outlet Type	Sink	9:25
Sample Number	169.1-83	Art Room 151 Front Sink Left	Outlet Type	Sink	9:26
Sample Number	169.1-84	Art Room 151 Front Sink Center	Outlet Type	Sink	9:27
Sample Number	169.1-85	Art Room 151 Front Sink Right	Outlet Type	Sink	9:28
Sample Number	169.1-86	Art Room 151 Back Sink Left	Outlet Type	Sink	9:29
Sample Number	169.1-87	Art Room 151 Back Sink Center	Outlet Type	Sink	9:30
Sample Number	169.1-88	Art Room 151 Back Sink Right	Outlet Type	Sink	9:31
Sample Number	169.1-89	Art Room 150 Front Sink Left	Outlet Type	Sink	9:32
Sample Number	169.1-90	Art Room 150 Front Sink Center	Outlet Type	Sink	9:33
Sample Number	169.1-91	Art Room 150 Front Sink Right	Outlet Type	Sink	9:34
Sample Number	169.1-92	Art Room 150 Back Sink Left	Outlet Type	Sink	9:35
Sample Number	169.1-93	Art Room 150 Back Sink Center	Outlet Type	Sink	9:36
Sample Number	169.1-94	Art Room 150 Back Sink Right	Outlet Type	Sink	9:37
Sample Number	169.1-95A	Art Room 150 Hallway	Outlet Type	D F A	9:38
Sample Number	169.1-95B	Art Room 150 Hallway	Outlet Type	D F B	9:39
Sample Number	169.1-96	Stage Room 174.3	Outlet Type	Sink	9:40
Sample Number	169.1-97	Art Room 149 Left	Outlet Type	Sink	9:41
Sample Number	169.1-98	Art Room 149 Left Center	Outlet Type	Sink	9:42
Sample Number	169.1-99	Art Room 149 Right Center	Outlet Type	Sink	9:43
Sample Number	169.1-100	Art Room 149 Right	Outlet Type	Sink	9:44
Sample Number	169.1-101	Art Room 147 Hallway	Outlet Type	D F A	9:45
Sample Number	169.1-102	Art Room 147 Left	Outlet Type	Sink	9:46
Sample Number	169.1-103	Art Room 147 Right	Outlet Type	Sink	9:47
Sample Number	169.1-104	Room 146	Outlet Type	Sink	9:48
Sample Number	169.1-105	Room 145	Outlet Type	Sink	9:49
Sample Number	169.1-106	Room 143B	Outlet Type	Sink	9:50
Sample Number	169.1-107	Room 143 Hallway	Outlet Type	D F A	9:51
Sample Number	169.1-108	143 Hall Women's Faculty Left	Outlet Type	Sink	9:52
Sample Number	169.1-109	143 Hall Women's Faculty Right	Outlet Type	Sink	9:53
Sample Number	169.1-110	143 Hallway Men's Faculty Left	Outlet Type	Sink	9:54
Sample Number	169.1-111	Credit Union 140	Outlet Type	Sink	9:55
Sample Number	169.1-112	Boys Lavatory B 7	Outlet Type	Sink	9:56
Sample Number	169.1-113	Room 138 Hallway	Outlet Type	D F A	9:57
Sample Number	169.1-114	Girls Lavatory G 7-Left	Outlet Type	Sink	9:58
Sample Number	169.1-115	Girls Lavatory G 7 Center	Outlet Type	Sink	9:59
Sample Number	169.1-116	Girls Lavatory G 7 Right	Outlet Type	Sink	10:00
Sample Number	169.1-117	Room 141 Left	Outlet Type	Sink	10:01
Sample Number	169.1-118	Room 141 Right	Outlet Type	Sink	10:02
Sample Number	169.1-119	Room 138A	Outlet Type	Sink	10:03
Sample Number	169.1-120	Room 136A	Outlet Type	Sink	10:04
Sample Number	169.1-121	Room 133 Hallway	Outlet Type	Sink	10:05
Sample Number	169.1-122	Fitness Center 163	Outlet Type	D F A	10:06

Sample Number	169.1-123	Fitness Center Pool Hallway	Outlet Type	D F A	10:07
Sample Number	169.1-124	Girls Pool Locker Room	Outlet Type	Bubbler	10:08
Sample Number	169.1-125	Girls Pool Locker Room	Outlet Type	Sink	10:09
Sample Number	169.1-126	Girls Pool Vestibule	Outlet Type	Sink	10:10
Sample Number	169.1-127A	Room 174 Hallway	Outlet Type	D F A	10:11
Sample Number	169.1-127B	Room 174 Hallway	Outlet Type	D F B	10:12
Sample Number	169.1-128	Accessible Lavatory	Outlet Type	Sink	10:13
Sample Number	169.1-129	Men's Main Office Front Left	Outlet Type	Sink	10:14
Sample Number	169.1-130	Men's Main Office Back Left	Outlet Type	Sink	10:15
Sample Number	169.1-131	Men's Main Office Back Right	Outlet Type	Sink	10:16
Sample Number	169.1-132	Men's Main Office Front Right	Outlet Type	Sink	10:17
Sample Number	169.1-133	Women's Main Office Left	Outlet Type	Sink	10:18
Sample Number	169.1-134	Women's Main Office Center	Outlet Type	Sink	10:19
Sample Number	169.1-135	Women's Main Office Right	Outlet Type	Sink	10:20
Sample Number	169.1-136	Principal's Office Lavatory	Outlet Type	Sink	10:21
Sample Number	169.1-137	Main Office Lavatory	Outlet Type	Sink	10:22
Sample Number	169.1-138A	Main Office Hallway	Outlet Type	D F A	10:23
Sample Number	169.1-138B	Main Office Hallway	Outlet Type	D F B	10:24
Sample Number	169.1-139	Room 184 Lounge	Outlet Type	Sink	10:25
Sample Number	169.1-140	Nurse Office Lavatory	Outlet Type	Sink	10:26
Sample Number	169.1-141	Nurse Office Kitchen	Outlet Type	Sink	10:27
Sample Number	169.1-142	Room 102 Hallway Lavatory	Outlet Type	Sink	10:28
Sample Number	169.1-143	Room 105 Hallway	Outlet Type	D F A	10:29
Sample Number	169.1-144	Ladies Lavatory G3 Left	Outlet Type	Sink	10:30
Sample Number	169.1-145	Ladies Lavatory G3 Center	Outlet Type	Sink	10:31
Sample Number	169.1-146	Ladies Lavatory G3 Right	Outlet Type	Sink	10:32
Sample Number	169.1-147	Men's Lavatory B3 Left	Outlet Type	Sink	10:33
Sample Number	169.1-148	Men's Lavatory B3 Center	Outlet Type	Sink	10:34
Sample Number	169.1-149	Men's Lavatory B3 Right	Outlet Type	Sink	10:35
Sample Number	169.1-150	Room 111A (Office Area)	Outlet Type	Sink	10:36
Sample Number	169.1-151	Room 114	Outlet Type	Sink	10:37
Sample Number	169.1-152	Room 114A	Outlet Type	Sink	10:38
Sample Number	169.1-153	Room 116 Hallway	Outlet Type	D F A	10:39
Sample Number	169.1-154	Room 116	Outlet Type	Sink	10:40
Sample Number	169.1-155	S11 S12 Prep Room	Outlet Type	Sink	10:41
Sample Number	169.1-156	S13 Hallway	Outlet Type	D F A	10:42
Sample Number	169.1-157	S13 S14 Prep Room	Outlet Type	Sink	10:43
Sample Number	169.1-158	S15 S16 Prep Room	Outlet Type	Sink	10:44
Sample Number	169.1-159	Room 124	Outlet Type	Sink	10:45
Sample Number	169.1-160	Room 125 Hallway	Outlet Type	D F A	10:46
Sample Number	169.1-161	Room 128A	Outlet Type	Sink	10:47
Sample Number	169.1-162	Boys Lavatory B 5 Left	Outlet Type	Sink	10:48
Sample Number	169.1-163	Boys Lavatory B 5 Right	Outlet Type	Sink	10:49
Sample Number	169.1-164	Girls Lavatory G 5 Left	Outlet Type	Sink	10:50
Sample Number	169.1-165	Girls Lavatory G 5 Center	Outlet Type	Sink	10:51
Sample Number	169.1-166	Girls Lavatory G 5 Right	Outlet Type	Sink	10:52
Sample Number	169.1-167	Room 128 Front	Outlet Type	Sink	10:53
Sample Number	169.1-168	Room 128 Back	Outlet Type	Sink	10:54
Sample Number	169.1-169	Room 130A	Outlet Type	Sink	10:55
Sample Number	169.1-170	Room 129 Front	Outlet Type	Sink	10:56
Sample Number	169.1-171	Room 129 Back	Outlet Type	Sink	10:57
Sample Number	169.1-172	Room 131A	Outlet Type	Sink	10:58
Sample Number	169.1-173	Room 130 Front	Outlet Type	Sink	10:59
Sample Number	169.1-174	Room 130 North Wall Center	Outlet Type	Sink	11:00
Sample Number	169.1-175	Room 131 Front	Outlet Type	Sink	11:01
Sample Number	169.1-176	Room 131 Back	Outlet Type	Sink	11:02
Sample Number	169.1-177	Faculty Lavatory 112 B Left	Outlet Type	Sink	11:03
Sample Number	169.1-178	Faculty Lavatory 112 B Right	Outlet Type	Sink	11:04

Sample Number	169.1-179	Faculty Lavatory 112 A Left	Outlet Type	Sink	11:05
Sample Number	169.1-180	Faculty Lavatory 112 A Right	Outlet Type	Sink	11:06
Sample Number	169.1-181	Second Floor North Men's Faculty Left	Outlet Type	Sink	11:07
Sample Number	169.1-182	Second Floor North Men's Faculty Center	Outlet Type	Sink	11:08
Sample Number	169.1-183	Second Floor North Men's Faculty Right	Outlet Type	Sink	11:09
Sample Number	169.1-184	Second Floor North Women's Faculty Left	Outlet Type	Sink	11:10
Sample Number	169.1-185	Second Floor North Women's Faculty Left Center	Outlet Type	Sink	11:11
Sample Number	169.1-186	Second Floor North Women's Faculty Right Center	Outlet Type	Sink	11:12
Sample Number	169.1-187	Second Floor North Women's Faculty Right	Outlet Type	Sink	11:13
Sample Number	169.1-188	Room 200.10	Outlet Type	Sink	11:14
Sample Number	169.1-189	Room 200.10 Hallway	Outlet Type	D F A	11:15
Sample Number	169.1-190	Room 207 Hallway	Outlet Type	D F A	11:16
Sample Number	169.1-191	Girls Lavatory G 4 Left	Outlet Type	Sink	11:17
Sample Number	169.1-192	Girls Lavatory G 4 Center	Outlet Type	Sink	11:18
Sample Number	169.1-193	Girls Lavatory G 4 Right	Outlet Type	Sink	11:19
Sample Number	169.1-194	Boys Lavatory B 4 Left	Outlet Type	Sink	11:20
Sample Number	169.1-195	Boys Lavatory B 4 Center	Outlet Type	Sink	11:21
Sample Number	169.1-196	Boys Lavatory B 4 Right	Outlet Type	Sink	11:22
Sample Number	169.1-197	Room 210	Outlet Type	Sink	11:23
Sample Number	169.1-199	Faculty Room 243 Ladies Lavatory	Outlet Type	Sink	11:24
Sample Number	169.1-200	Faculty Room 243 Men's Lavatory	Outlet Type	Sink	11:25
Sample Number	169.1-201	Faculty Room 243 Kitchenette	Outlet Type	Sink	11:26
Sample Number	169.1-202	Boys Lavatory B 8 left	Outlet Type	Sink	11:27
Sample Number	169.1-203	Boys Lavatory B 8 Center	Outlet Type	Sink	11:28
Sample Number	169.1-204	Boys Lavatory B8 Right	Outlet Type	Sink	11:29
Sample Number	169.1-205	Between Lavatories B 8-and G 8	Outlet Type	D F A	11:30
Sample Number	169.1-206	Girls Lavatory G 8 Left	Outlet Type	Sink	11:31
Sample Number	169.1-207	Girls Lavatory G 8 Center	Outlet Type	Sink	11:32
Sample Number	169.1-208	Girls Lavatory G 8 right	Outlet Type	Sink	11:33
Sample Number	169.1-209	Room 233 Hallway	Outlet Type	D F A	11:34
Sample Number	169.1-210	Room 227 Hallway	Outlet Type	D F A	11:35
Sample Number	169.1-211	Girls Lavatory G 6 Left	Outlet Type	Sink	11:36
Sample Number	169.1-212	Girls Lavatory G 6 Center	Outlet Type	Sink	11:37
Sample Number	169.1-213	Girls Lavatory G 6 Right	Outlet Type	Sink	11:38
Sample Number	169.1-214	Boys Lavatory B 6 Left	Outlet Type	Sink	11:39
Sample Number	169.1-215	Boys Lavatory B 6 Right	Outlet Type	Sink	11:40
Sample Number	169.1-216	Boys South Lavatory Left	Outlet Type	Sink	11:41
Sample Number	169.1-217	Boys South Lavatory Right	Outlet Type	Sink	11:42
Sample Number	169.1-218	South End Lobby Left	Outlet Type	D F A	11:43
Sample Number	169.1-219	South End Lobby Right	Outlet Type	D F A	11:44
Sample Number	169.1-220	Girls South Lavatory Left	Outlet Type	Sink	11:45
Sample Number	169.1-221	Girls South Lavatory Right	Outlet Type	Sink	11:46
Sample Number	169.1-222	Room 216	Outlet Type	Sink	11:47
Sample Number	169.1-223	Room 217 North	Outlet Type	Sink	11:48
Sample Number	169.1-224	Room 217 South	Outlet Type	Sink	11:49
Sample Number	169.1-225	Room 217 Southwest	Outlet Type	Sink	11:50
Sample Number	169.1-226	Room 217 Northwest	Outlet Type	Sink	11:51
Sample Number	169.1-228	Room 221.2	Outlet Type	Sink	11:52
Sample Number	169.1-229	Media Center 245.2	Outlet Type	Sink	11:53
Sample Number	169.1-230	Basement Rifle Range Hallway	Outlet Type	Sink	11:54
Sample Number	169.1-231	Basement Rifle Range Hallway	Outlet Type	D F A	11:55
Sample Number	169.1-232	Basement Laundry Room	Outlet Type	Sink	11:56
Sample Number	169.1-233	Basement Staff Lavatory	Outlet Type	Sink	11:57

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: C. Schultz and P. Nichols Stohl Environmental 10/17/2020

Relinquished By: Eric Henderson Jr. 10/19/2020

Received (Name, Laboratory): K T Harris 10/22/20 at 10:32am

Sample Login (Name, Laboratory): Traci Bloom 11/16/2020 at 3:57pm

Analysis (Name, Laboratory): J. Hertzler 11/16/2020 at 8:40am

Archived, Released: signature 11/17/2020 at 3:00pm