

June 3, 2021

Mr. Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, NY 14086

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:

- Lancaster High School – 1 Forton Drive, Lancaster, New York.

This report is prepared at the request of the District to identifying the sources of water within Laboratory classroom faucets with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on February 27, 2021. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 69 Laboratory Sinks in the High School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Water Sources
For Lead Concentrations**

Prepared for:

Lancaster Central School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Lancaster High School

Conditions as of February 27, 2021

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Lancaster High School – 1 Forton Drive, Lancaster, New York.

Scope of Work:

At the direction of the District, Stohl Environmental was charged with collecting first-draw water samples from outlets within the High School Laboratory Sinks. Laboratory sinks do not meet the definition of an outlet according to NYS. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
High School Lab Sinks	2/27/2021	170	101	69	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
169.1-234	Lab 138 North Wall Left	Sink	47.1
169.1-235	Lab Room 138 North Wall Right	Sink	67.2
169.1-236	Lab Room 138 East Wall Left	Sink	22.7
169.1-238	Lab Room 138 Teacher Desk	Sink	62.1
169.1-239	Lab Room 136 Teacher Desk	Sink	43.9
169.1-241	Lab Room 136 East Wall Right	Sink	16.9
169.1-242	Lab Room 136 South Wall Left	Sink	38.6
169.1-243	Lab Room 136 South Wall Right	Sink	41.4
169.1-244	Lab Room 134 West Wall South Sink Left	Sink	16.6
169.1-248	Lab Room 134 West Wall North Sink Left	Sink	28.1
169.1-249	Lab Room 134 West Wall North Sink Right	Sink	16.9
169.1-250	Lab Room 134 Teacher Desk North	Sink	15.8
169.1-251	Lab Room 134 Teacher Desk South	Sink	21.6
169.1-252	Lab Room 134 South Wall East Sink Left	Sink	46.9
169.1-254	Lab Room 134 South Wall Center Sink Left	Sink	22.4
169.1-257	Lab Room 134 South Wall West Sink Right	Sink	198
169.1-261	Lab Room 130 North Wall West Sink Right	Sink	44.2
169.1-265	Lab Room 130 North Wall East Sink Right	Sink	47.9
169.1-268	Lab Room 130 East Wall Center Sink Left	Sink	28.6
169.1-269	Lab Room 130 East Wall Center Sink Right	Sink	25.4
169.1-272	Prep Room 130A Left	Sink	16.8
169.1-274	Lab Room 128 Teacher Desk Left	Sink	26.9
169.1-277	Prep Room 128A Left	Sink	38.7
169.1-284	Room 131A Left	Sink	18.9
169.1-286	Room 131 Teacher Desk Left	Sink	63.4
169.1-290	Lab S16 East Wall North Sink Left	Sink	33.2
169.1-291	La S16 East Wall North Sink Right	Sink	53.1
169.1-292	Lab S16 East Wall 2nd North Sink Left	Sink	97.3
169.1-293	Lab S16 East Wall 2nd North Sink Right	Sink	34.7
169.1-294	Lab S16 East Wall 2nd South Sink Left	Sink	37.6
169.1-295	Lab S16 East Wall 2nd South Sink Right	Sink	24.2
169.1-296	Lab S16 East Wall South Sink Left	Sink	26.3
169.1-297	Lab S16 East Wall South Sink Right	Sink	27.9

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
169.1-298	Lab S16 South Wall East Sink Left	Sink	18.9
169.1-300	Lab S16 South Wall Center Sink Left	Sink	19.2
169.1-301	Lab S16 South Wall Center Sink Right	Sink	25.9
169.1-302	Lab S16 South Wall Right Sink	Sink	57.3
169.1-303	Lab S16 Teachers Desk	Sink	73.6
169.1-305	Lab S15 Teachers Desk	Sink	29.3
169.1-306	Lab S15 South Wall East Sink	Sink	100
169.1-308	Lab S15 South Wall Center Sink Right	Sink	16.8
169.1-313	Lab S15 West Wall 2nd South Sink Left	Sink	15.1
169.1-319	Lab S15 North Wall	Sink	32.2
169.1-320	Lab S14 North Wall	Sink	31.9
169.1-333	Lab S14 South Wall West Sink	Sink	34.1
169.1-334	Lab S14 Teacher Desk	Sink	31.4
169.1-336	Lab S13 Teacher Desk	Sink	22.0
169.1-337	Lab S13 South Wall East Sink	Sink	71.7
169.1-350	Lab S13 North Wall	Sink	16.1
169.1-351	Lab S12 North Wall	Sink	18.6
169.1-364	Lab S12 South Wall West Sink	Sink	57.6
169.1-365	Lab S12 Teacher Desk	Sink	55.5
169.1-367	Lab S11 Teacher Desk	Sink	58.7
169.1-368	Lab S11 South Wall East Sink	Sink	32.2
169.1-381	Lab S11 North Wall	Sink	22.9
169.1-382	Lab 111 Teacher Desk Left	Sink	252
169.1-383	Lab 111 Teacher Desk Right	Sink	179
169.1-386	Lab 111 West Wall Center Sink Left	Sink	26.1
169.1-388	Lab 111 West Wall North Sink Left	Sink	28.7
169.1-398	Lab 109 Teachers Desk	Sink	46.3
169.1-399	Lab 109 West Wall	Sink	38.6
169.1-402	Lab 109 West Row Center Sink Left	Sink	23.1
169.1-403	Lab 109 West Row Center Sink Right	Sink	44.2
169.1-404	Lab 109 West Row North Sink Left	Sink	21.8
169.1-405	Lab 109 West Row North Sink Right	Sink	28.8
169.1-406	Lab 109 East Row North Sink Left	Sink	27.5
169.1-407	Lab 109 East Row North Sink Right	Sink	18.4
169.1-409	Lab 109 East Row Center Sink Right	Sink	18.5
169.1-412	Lab 107 West Wall South Sink	Sink	16.3

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-03-00593

Received Date: 03/03/2021
Reported Date: 03/31/2021
Sampled By:
Tech Certification #:

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive; Lancaster, NY 14086

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-001	169.1-234	02/27/2021	LAB 138 NORTH WALL LEFT	47.1	03/22/2021	
21-03-00593-002	169.1-235	02/27/2021	LAB ROOM 138 NORTH WALL RIGHT	67.2	03/22/2021	
21-03-00593-003	169.1-236	02/27/2021	LAB ROOM 138 EAST WALL LEFT	22.7	03/22/2021	
21-03-00593-004	169.1-237	02/27/2021	LAB ROOM 138 EAST WALL RIGHT	13.5	03/22/2021	
21-03-00593-005	169.1-238	02/27/2021	LAB ROOM 138 TEACHER DESK	62.1	03/22/2021	
21-03-00593-006	169.1-239	02/27/2021	LAB ROOM 136 TEACHER DESK	43.9	03/22/2021	
21-03-00593-007	169.1-240	02/27/2021	LAB ROOM 136 EAST WALL LEFT	7.23	03/22/2021	
21-03-00593-008	169.1-241	02/27/2021	LAB ROOM 136 EAST WALL RIGHT	16.9	03/22/2021	
21-03-00593-009	169.1-242	02/27/2021	LAB ROOM 136 SOUTH WALL LEFT	38.6	03/22/2021	
21-03-00593-010	169.1-243	02/27/2021	LAB ROOM 136 SOUTH WALL RIGHT	41.4	03/22/2021	
21-03-00593-011	169.1-244	02/27/2021	LAB ROOM 134 WEST WALL SOUTH SINK LEFT	16.6	03/22/2021	
21-03-00593-012	169.1-246	02/27/2021	LAB ROOM 134 WEST WALL CENTER SINK LEFT	11.8	03/23/2021	
21-03-00593-013	169.1-247	02/27/2021	LAB ROOM 134 WEST WALL CENTER SINK RIGHT	11.4	03/23/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-014	169.1-248	02/27/2021	LAB ROOM 134 WEST WALL NORTH SINK LEFT	28.1	03/23/2021	
21-03-00593-015	169.1-249	02/27/2021	LAB ROOM 134 WEST WALL NORTH SINK RIGHT	16.9	03/23/2021	
21-03-00593-016	169.1-250	02/27/2021	LAB ROOM 134 TEACHER DESK NORTH	15.8	03/23/2021	
21-03-00593-017	169.1-251	02/27/2021	LAB ROOM 134 TEACHER DESK SOUTH	21.6	03/23/2021	
21-03-00593-018	169.1-252	02/27/2021	LAB ROOM 134 SOUTH WALL EAST SINK LEFT	46.9	03/23/2021	
21-03-00593-019	169.1-253	02/27/2021	LAB ROOM 134 SOUTH WALL EAST SINK RIGHT	6.99	03/22/2021	
21-03-00593-020	169.1-254	02/27/2021	LAB ROOM 134 SOUTH WALL CENTER SINK LEFT	22.4	03/23/2021	
21-03-00593-021	169.1-255	02/27/2021	LAB ROOM 134 SOUTH WALL CENTER SINK RIGHT	2.94	03/22/2021	
21-03-00593-022	169.1-256	02/27/2021	LAB ROOM 134 SOUTH WALL WEST SINK LEFT	7.90	03/22/2021	
21-03-00593-023	169.1-257	02/27/2021	LAB ROOM 134 SOUTH WALL WEST SINK RIGHT	198	03/23/2021	
21-03-00593-024	169.1-258	02/27/2021	LAB ROOM 130 TEACHER DESK NORTH	1.74	03/22/2021	
21-03-00593-025	169.1-260	02/27/2021	LAB ROOM 130 NORTH WALL WEST SINK LEFT	12.5	03/23/2021	
21-03-00593-026	169.1-261	02/27/2021	LAB ROOM 130 NORTH WALL WEST SINK RIGHT	44.2	03/23/2021	
21-03-00593-027	169.1-262	02/27/2021	LAB ROOM 130 NORTH WALL CENTER SINK LEFT	9.21	03/22/2021	
21-03-00593-028	169.1-263	02/27/2021	LAB ROOM 130 NORTH WALL CENTER SINK RIGHT	4.92	03/22/2021	
21-03-00593-029	169.1-264	02/27/2021	LAB ROOM 130 NORTH WALL EAST SINK LEFT	8.70	03/22/2021	
21-03-00593-030	169.1-265	02/27/2021	LAB ROOM 130 NORTH WALL EAST SINK RIGHT	47.9	03/23/2021	
21-03-00593-031	169.1-266	02/27/2021	LAB ROOM 130 EAST WALL NORTH SINK LEFT	9.90	03/22/2021	
21-03-00593-032	169.1-267	02/27/2021	LAB ROOM 130 EAST WALL NORTH SINK RIGHT	4.44	03/22/2021	
21-03-00593-033	169.1-268	02/27/2021	LAB ROOM 130 EAST WALL CENTER SINK LEFT	28.6	03/23/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-034	169.1-269	02/27/2021	LAB ROOM 130 EAST WALL CENTER SINK RIGHT	25.4	03/23/2021	
21-03-00593-035	169.1-270	02/27/2021	LAB ROOM 130 EAST WALL SOUTH SINK LEFT	14.9	03/23/2021	
21-03-00593-036	169.1-271	02/27/2021	LAB ROOM 130 EAST WALL SOUTH SINK RIGHT	12.3	03/23/2021	
21-03-00593-037	169.1-272	02/27/2021	PREP ROOM 130A LEFT	16.8	03/23/2021	
21-03-00593-038	169.1-274	02/27/2021	LAB ROOM 128 TEACHER DESK LEFT	26.9	03/23/2021	
21-03-00593-039	169.1-277	02/27/2021	PREP ROOM 128A LEFT	38.7	03/23/2021	
21-03-00593-040	169.1-279	02/27/2021	ROOM 126 TEACHER DESK LEFT	6.63	03/22/2021	
21-03-00593-041	169.1-280	02/27/2021	ROOM 126 TEACHER DESK RIGHT	8.01	03/22/2021	
21-03-00593-042	169.1-281	02/27/2021	ROOM 129 TEACHER DESK LEFT	4.41	03/22/2021	
21-03-00593-043	169.1-284	02/27/2021	ROOM 131A LEFT	18.9	03/23/2021	
21-03-00593-044	169.1-286	02/27/2021	ROOM 131 TEACHER DESK LEFT	63.4	03/23/2021	
21-03-00593-045	169.1-289	02/27/2021	LAB S16 NORTH WALL	2.50	03/22/2021	
21-03-00593-046	169.1-290	02/27/2021	LAB S16 EAST WALL NORTH SINK LEFT	33.2	03/23/2021	
21-03-00593-047	169.1-291	02/27/2021	LAB S16 EAST WALL NORTH SINK RIGHT	53.1	03/23/2021	
21-03-00593-048	169.1-292	02/27/2021	LAB S16 EAST WALL 2ND NORTH SINK LEFT	97.3	03/23/2021	
21-03-00593-049	169.1-293	02/27/2021	LAB S16 EAST WALL 2ND NORTH SINK RIGHT	34.7	03/23/2021	
21-03-00593-050	169.1-294	02/27/2021	LAB S16 EAST WALL 2ND SOUTH SINK LEFT	37.6	03/23/2021	
21-03-00593-051	169.1-295	02/27/2021	LAB S16 EAST WALL 2ND SOUTH SINK RIGHT	24.2	03/24/2021	
21-03-00593-052	169.1-296	02/27/2021	LAB S16 EAST WALL SOUTH SINK LEFT	26.3	03/24/2021	
21-03-00593-053	169.1-297	02/27/2021	LAB S16 EAST WALL SOUTH SINK RIGHT	27.9	03/24/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-054	169.1-298	02/27/2021	LAB S16 SOUTH WALL EAST SINK LEFT	18.9	03/24/2021	
21-03-00593-055	169.1-299	02/27/2021	LAB S16 SOUTH WALL EAST SINK RIGHT	10.2	03/24/2021	
21-03-00593-056	169.1-300	02/27/2021	LAB S16 SOUTH WALL CENTER SINK LEFT	19.2	03/24/2021	
21-03-00593-057	169.1-301	02/27/2021	LAB S16 SOUTH WALL CENTER SINK RIGHT	25.9	03/24/2021	
21-03-00593-058	169.1-302	02/27/2021	LAB S16 SOUTH WALL RIGHT SINK	57.3	03/24/2021	
21-03-00593-059	169.1-303	02/27/2021	LAB S16 TEACHERS DESK	73.6	03/24/2021	
21-03-00593-060	169.1-305	02/27/2021	LAB S15 TEACHERS DESK	29.3	03/24/2021	
21-03-00593-061	169.1-306	02/27/2021	LAB S15 SOUTH WALL EAST SINK	100	03/24/2021	
21-03-00593-062	169.1-307	02/27/2021	LAB S15 SOUTH WALL CENTER SINK LEFT	8.08	03/24/2021	
21-03-00593-063	169.1-308	02/27/2021	LAB S15 SOUTH WALL CENTER SINK RIGHT	16.8	03/24/2021	
21-03-00593-064	169.1-309	02/27/2021	LAB S15 SOUTH WALL WEST SINK LEFT	4.99	03/24/2021	
21-03-00593-065	169.1-310	02/27/2021	LAB S15 SOUTH WALL WEST SINK RIGHT	4.69	03/23/2021	
21-03-00593-066	169.1-311	02/27/2021	LAB S15 WEST WALL SOUTH SINK LEFT	10.5	03/24/2021	
21-03-00593-067	169.1-312	02/27/2021	LAB S15 WEST WALL SOUTH SINK RIGHT	11.3	03/24/2021	
21-03-00593-068	169.1-313	02/27/2021	LAB S15 WEST WALL 2ND SOUTH SINK	15.1	03/24/2021	
21-03-00593-069	169.1-314	02/27/2021	LAB S15 WEST WALL 2ND SOUTH SINK RIGHT	7.04	03/24/2021	
21-03-00593-070	169.1-315	02/27/2021	LAB S15 WEST WALL 2ND NORTH SINK LEFT	3.01	03/24/2021	
21-03-00593-071	169.1-316	02/27/2021	LAB S15 WEST WALL 2ND NORTH SINK RIGHT	8.08	03/24/2021	
21-03-00593-072	169.1-317	02/27/2021	LAB S15 WEST WALL NORTH SINK LEFT	8.39	03/24/2021	
21-03-00593-073	169.1-318	02/27/2021	LAB S15 WEST WALL NORTH SINK	7.51	03/24/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-074	169.1-319	02/27/2021	LAB S15 NORTH WALL	32.2	03/24/2021	
21-03-00593-075	169.1-320	02/27/2021	LAB S14 NORTH WALL	31.9	03/25/2021	
21-03-00593-076	169.1-321	02/27/2021	LAB S14 EAST WALL NORTH SINK LEFT	2.42	03/24/2021	
21-03-00593-077	169.1-322	02/27/2021	LAB S14 EAST WALL NORTH SINK RIGHT	3.22	03/24/2021	
21-03-00593-078	169.1-323	02/27/2021	LAB S14 EAST WALL 2ND NORTH SINK LEFT	1.71	03/24/2021	
21-03-00593-079	169.1-324	02/27/2021	LAB S14 EAST WALL 2ND NORTH SINK RIGHT	6.54	03/24/2021	
21-03-00593-080	169.1-325	02/27/2021	LAB S14 EAST WALL 2ND SOUTH SINK LEFT	2.78	03/24/2021	
21-03-00593-081	169.1-326	02/27/2021	LAB S14 EAST WALL 2ND SOUTH SINK RIGHT	3.39	03/24/2021	
21-03-00593-082	169.1-327	02/27/2021	LAB S14 EAST WALL SOUTH SINK LEFT	4.35	03/24/2021	
21-03-00593-083	169.1-328	02/27/2021	LAB S14 EAST WALL SOUTH SINK RIGHT	4.54	03/24/2021	
21-03-00593-084	169.1-329	02/27/2021	LAB S14 SOUTH WALL EAST SINK LEFT	4.07	03/24/2021	
21-03-00593-085	169.1-330	02/27/2021	LAB S14 SOUTH WALL EAST SINK RIGHT	2.80	03/24/2021	
21-03-00593-086	169.1-331	02/27/2021	LAB S14 SOUTH WALL CENTER SINK LEFT	1.28	03/24/2021	
21-03-00593-087	169.1-332	02/27/2021	LAB S14 SOUTH WALL CENTER SINK RIGHT	<1.00	03/24/2021	
21-03-00593-088	169.1-333	02/27/2021	LAB S14 SOUTH WALL WEST SINK	34.1	03/25/2021	
21-03-00593-089	169.1-334	02/27/2021	LAB S14 TEACHER DESK	31.4	03/25/2021	
21-03-00593-090	169.1-336	02/27/2021	LAB S13 TEACHER DESK	22.0	03/25/2021	
21-03-00593-091	169.1-337	02/27/2021	LAB S13 SOUTH WALL EAST SINK	71.7	03/25/2021	
21-03-00593-092	169.1-338	02/27/2021	LA S13 SOUTH WALL CENTER SINK LEFT	1.69	03/24/2021	
21-03-00593-093	169.1-339	02/27/2021	LAB S13 SOUTH WALL CENTER SINK RIGHT	2.83	03/24/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-094	169.1-340	02/27/2021	LAB S13 SOUTH WALL WEST SINK LEFT	2.18	03/24/2021	
21-03-00593-095	169.1-341	02/27/2021	LAB S13 SOUTH WALL WEST SINK RIGHT	4.02	03/24/2021	
21-03-00593-096	169.1-342	02/27/2021	LAB S13 WEST WALL SOUTH SINK LEFT	5.81	03/24/2021	
21-03-00593-097	169.1-343	02/27/2021	LAB S13 WEST WALL SOUTH SINK RIGHT	2.46	03/24/2021	
21-03-00593-098	169.1-344	02/27/2021	LAB S13 WEST WALL 2ND SOUTH SINK LEFT	3.80	03/24/2021	
21-03-00593-099	169.1-345	02/27/2021	LAB S13 WEST WALL 2ND SOUTH SINK RIGHT	5.27	03/24/2021	
21-03-00593-100	169.1-346	02/27/2021	LAB S13 WEST WALL 2ND NORTH SINK LEFT	4.14	03/24/2021	
21-03-00593-101	169.1-347	02/27/2021	LAB S13 WEST WALL 2ND NORTH SINK RIGHT	5.69	03/24/2021	
21-03-00593-102	169.1-348	02/27/2021	LAB S13 WEST WALL NORTH SINK LEFT	2.37	03/24/2021	
21-03-00593-103	169.1-349	02/27/2021	LAB S13 WEST WALL NORTH SINK RIGHT	4.13	03/24/2021	
21-03-00593-104	169.1-350	02/27/2021	LAB S13 NORTH WALL	16.1	03/25/2021	
21-03-00593-105	169.1-351	02/27/2021	LAB S12 NORTH WALL	18.6	03/25/2021	
21-03-00593-106	169.1-352	02/27/2021	LAB S12 EAST WALL NORTH SINK LEFT	3.20	03/24/2021	
21-03-00593-107	169.1-353	02/27/2021	LAB S12 EAST WALL NORTH SINK RIGHT	4.35	03/24/2021	
21-03-00593-108	169.1-354	02/27/2021	LAB S12 EAST WALL 2ND NORTH SINK LEFT	1.61	03/24/2021	
21-03-00593-109	169.1-355	02/27/2021	LAB S12 EAST WALL 2ND NORTH SINK RIGHT	2.96	03/24/2021	
21-03-00593-110	169.1-356	02/27/2021	LAB S12 EAST WALL 2ND SOUTH SINK LEFT	2.07	03/24/2021	
21-03-00593-111	169.1-357	02/27/2021	LAB S12 EAST WALL 2ND SOUTH SINK RIGHT	1.93	03/24/2021	
21-03-00593-112	169.1-358	02/27/2021	LAB S12 EAST WALL 2ND SOUTH SINK LEFT	1.26	03/24/2021	
21-03-00593-113	169.1-359	02/27/2021	LAB S12 EAST WALL SOUTH SINK RIGHT	1.79	03/24/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-114	169.1-360	02/27/2021	LAB S12 SOUTH WALL EAST SINK LEFT	3.33	03/25/2021	
21-03-00593-115	169.1-361	02/27/2021	LAB S12 SOUTH WALL EAST SINK RIGHT	5.00	03/25/2021	
21-03-00593-116	169.1-362	02/27/2021	LAB S12 SOUTH WALL CENTER SINK LEFT	1.89	03/25/2021	
21-03-00593-117	169.1-363	02/27/2021	LAB S12 SOUTH WALL CENTER SINK RIGHT	2.12	03/25/2021	
21-03-00593-118	169.1-364	02/27/2021	LAB S12 SOUTH WALL WEST SINK	57.6	03/25/2021	
21-03-00593-119	169.1-365	02/27/2021	LAB S12 TEACHER DESK	55.5	03/26/2021	
21-03-00593-120	169.1-367	02/27/2021	LAB S11 TEACHER DESK	58.7	03/25/2021	
21-03-00593-121	169.1-368	02/27/2021	LAB S11 SOUTH WALL EAST SINK	32.2	03/26/2021	
21-03-00593-122	169.1-369	02/27/2021	LAB S11 SOUTH WALL CENTER SINK LEFT	2.90	03/25/2021	
21-03-00593-123	169.1-370	02/27/2021	LAB S11 SOUTH WALL CENTER SINK RIGHT	4.67	03/25/2021	
21-03-00593-124	169.1-371	02/27/2021	LAB S11 SOUTH WALL WEST SINK LEFT	2.09	03/25/2021	
21-03-00593-125	169.1-372	02/27/2021	LAB S11 SOUTH WALL WEST SINK RIGHT	5.77	03/25/2021	
21-03-00593-126	169.1-373	02/27/2021	LAB S11 WEST WALL SOUTH SINK LEFT	2.59	03/25/2021	
21-03-00593-127	169.1-374	02/27/2021	LAB S11 WEST WALL SOUTH SINK RIGHT	2.73	03/25/2021	
21-03-00593-128	169.1-375	02/27/2021	LAB S11 WEST WALL 2ND SOUTH SINK LEFT	2.22	03/25/2021	
21-03-00593-129	169.1-376	02/27/2021	LAB S11 WEST WALL 2ND SOUTH SINK RIGHT	3.05	03/25/2021	
21-03-00593-130	169.1-377	02/27/2021	LAB S11 WEST WALL 2ND NORTH SINK LEFT	2.96	03/25/2021	
21-03-00593-131	169.1-378	02/27/2021	LAB S11 WEST WALL 2ND NORTH SINK RIGHT	3.96	03/25/2021	
21-03-00593-132	169.1-379	02/27/2021	LAB S11 WEST WALL NORTH SINK LEFT	2.43	03/25/2021	
21-03-00593-133	169.1-380	02/27/2021	LAB S11 WEST WALL NORTH SINK RIGHT	3.41	03/25/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-134	169.1-381	02/27/2021	LAB S11 NORTH WALL	22.9	03/26/2021	
21-03-00593-135	169.1-382	02/27/2021	LAB 111 TEACHER DESK LEFT	252	03/29/2021	W01
21-03-00593-136	169.1-383	02/27/2021	LAB 111 TEACHER DESK RIGHT	179	03/29/2021	W01
21-03-00593-137	169.1-384	02/27/2021	LAB 111 WEST WALL SOUTH SINK LEFT	13.3	03/26/2021	
21-03-00593-138	169.1-385	02/27/2021	LAB 111 WEST WALL SOUTH SINK RIGHT	13.8	03/26/2021	
21-03-00593-139	169.1-386	02/27/2021	LAB 111 WEST WALL CENTER SINK LEFT	26.1	03/26/2021	
21-03-00593-140	169.1-387	02/27/2021	LAB 111 WEST WALL CENTER SINK RIGHT	14.5	03/26/2021	
21-03-00593-141	169.1-388	02/27/2021	LAB 111 WEST WALL NORTH SINK LEFT	28.7	03/26/2021	
21-03-00593-142	169.1-389	02/27/2021	LAB 111 WEST WALL NORTH SINK RIGHT	4.53	03/26/2021	
21-03-00593-143	169.1-390	02/27/2021	LAB 111 EAST WALL NORTH SINK LEFT	9.58	03/26/2021	
21-03-00593-144	169.1-391	02/27/2021	LAB 111 EAST WALL NORTH SINK RIGHT	6.91	03/26/2021	
21-03-00593-145	169.1-392	02/27/2021	LAB 111 EAST WALL CENTER SINK LEFT	7.44	03/26/2021	
21-03-00593-146	169.1-393	02/27/2021	LAB 111 EAST WALL CENTER SINK RIGHT	7.94	03/26/2021	
21-03-00593-147	169.1-394	02/27/2021	LAB 111 EAST WALL SOUTH SINK LEFT	8.02	03/26/2021	
21-03-00593-148	169.1-395	02/27/2021	LAB 111 EAST WALL SOUTH SINK RIGHT	9.36	03/26/2021	
21-03-00593-149	169.1-396	02/27/2021	LAB 111 A OFFICE AREA LEFT	7.21	03/26/2021	
21-03-00593-150	169.1-398	02/27/2021	LAB 109 TEACHERS DESK	46.3	03/26/2021	
21-03-00593-151	169.1-399	02/27/2021	LAB 109 WEST WALL	38.6	03/26/2021	
21-03-00593-152	169.1-402	02/27/2021	LAB 109 WEST ROW CENTER SINK LEFT	23.1	03/26/2021	
21-03-00593-153	169.1-403	02/27/2021	LAB 109 WEST ROW CENTER SINK RIGHT	44.2	03/26/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-00593-154	169.1-404	02/27/2021	LAB 109 WEST ROW NORTH SINK LEFT	21.8	03/26/2021	
21-03-00593-155	169.1-405	02/27/2021	LAB 109 WEST ROW NORTH SINK RIGHT	28.8	03/26/2021	
21-03-00593-156	169.1-406	02/27/2021	LAB 109 EAST ROW NORTH SINK LEFT	27.5	03/26/2021	
21-03-00593-157	169.1-407	02/27/2021	LAB 109 EAST ROW NORTH SINK RIGHT	18.4	03/26/2021	
21-03-00593-158	169.1-408	02/27/2021	LAB 109 EAST ROW CENTER SINK LEFT	6.78	03/26/2021	
21-03-00593-159	169.1-409	02/27/2021	LAB 109 EAST ROW CENTER SINK RIGHT	18.5	03/26/2021	
21-03-00593-160	169.1-412	02/27/2021	LAB 107 WEST WALL SOUTH SINK	16.3	03/29/2021	
21-03-00593-161	169.1-415	02/27/2021	LAB 107 WEST WALL NORTH SINK LEFT	2.90	03/29/2021	
21-03-00593-162	169.1-416	02/27/2021	LAB 107 WEST WALL NORTH SINK RIGHT	3.69	03/29/2021	
21-03-00593-163	169.1-417	02/27/2021	LAB 107 NORTH WALL WEST SINK LEFT	4.30	03/29/2021	
21-03-00593-164	169.1-418	02/27/2021	LAB 107 NORTH WALL WEST SINK RIGHT	6.88	03/29/2021	
21-03-00593-165	169.1-419	02/27/2021	LAB 107 NORTH WALL EAST SINK LEFT	3.52	03/29/2021	
21-03-00593-166	169.1-420	02/27/2021	LAB 107 NORTH WALL EAST SINK RIGHT	8.47	03/29/2021	
21-03-00593-167	169.1-421	02/27/2021	LAB 107 EAST WALL NORTH SINK LEFT	2.64	03/29/2021	
21-03-00593-168	169.1-422	02/27/2021	LAB 107 EAST WALL NORTH SINK RIGHT	7.69	03/29/2021	
21-03-00593-169	169.1-423	02/27/2021	LAB 107 EAST WALL SOUTH SINK LEFT	9.53	03/29/2021	
21-03-00593-170	169.1-424	02/27/2021	LAB 107 EAST WALL SOUTH SINK RIGHT	6.03	03/29/2021	

Sample Narratives:

W01: LCS recovery was above acceptable range.

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-00593

Project/Test Address: 2020L-169-1; Lancaster High School; 1 Forton Drive;
Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory:



Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022
Issued April 01, 2021
Revised April 02, 2021

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Lead, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

NEW YORK
STATE OF
OPPORTUNITY.

Department
of Health

Serial No.: 63485

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD Contact: Michael Bryniarski

Building: Lancaster High School Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
169.1-234	Lab 138 North Wall Left	Sink	8:40
169.1-235	Lab Room 138 North Wall Right	Sink	8:42
169.1-236	Lab Room 138 East Wall Left	Sink	8:44
169.1-237	Lab Room 138 East Wall Right	Sink	8:46
169.1-238	Lab Room 138 Teacher Desk	Sink	8:48
169.1-239	Lab Room 136 Teacher Desk	Sink	8:50
169.1-240	Lab Room 136 East Wall Left	Sink	8:52
169.1-241	Lab Room 136 East Wall Right	Sink	8:54
169.1-242	Lab Room 136 South Wall Left	Sink	8:56
169.1-243	Lab Room 136 South Wall Right	Sink	8:58
169.1-244	Lab Room 134 West Wall South Sink Left	Sink	9:00
169.1-246	Lab Room 134 West Wall Center Sink Left	Sink	9:02
169.1-247	Lab Room 134 West Wall Center Sink Right	Sink	9:04
169.1-248	Lab Room 134 West Wall North Sink Left	Sink	9:06
169.1-249	Lab Room 134 West Wall North Sink Right	Sink	9:08
169.1-250	Lab Room 134 Teacher Desk North	Sink	9:10
169.1-251	Lab Room 134 Teacher Desk South	Sink	9:12
169.1-252	Lab Room 134 South Wall East Sink Left	Sink	9:14

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 2/27/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/1/2021

Received (Name / Lab): KTHARRIS K. Olaver Date: 3/3/21 Time: 11:44 AM

Sample Login (Name / Lab): Tina Blum / New Blum Date: 3/5/21 21-03-00593 8:24 AM

Analysis (Name / Lab): J. Hertler Date: 3/29/21 12:25 pm

QA/QC Review (Name / Lab): J. Eddy Date: 3/31/21 5:28 pm

Archived / Released: QA/QC InterLAB Use: Date: 03/31/2021

Due Date:
03/31/2021
(Wednesday)
AE

00593



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS
 STOHL Job # 2020L-169.1

L
27

Client: Lancaster CSD Contact: Michael Bryniarski
 Building: Lancaster High School Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround
20 Days

Sample #	Location	Outlet Type	Time
169.1-253	Lab Room 134 South Wall East Sink Right	Sink	9:16
169.1-254	Lab Room 134 South Wall Center Sink Left	Sink	9:18
169.1-255	Lab Room 134 South Wall Center Sink Right	Sink	9:20
169.1-256	Lab Room 134 South Wall West Sink Left	Sink	9:22
169.1-257	Lab Room 134 South Wall West Sink Right	Sink	9:24
169.1-258	Lab Room 130 Teacher Desk North	Sink	9:26
169.1-260	Lab Room 130 North Wall West Sink Left	Sink	9:28
169.1-261	Lab Room 130 North Wall West Sink Right	Sink	9:30
169.1-262	Lab Room 130 North Wall Center Sink Left	Sink	9:32
169.1-263	Lab Room 130 North Wall Center Sink Right	Sink	9:34
169.1-264	Lab Room 130 North Wall East Sink Left	Sink	9:36
169.1-265	Lab Room 130 North Wall East Sink Right	Sink	9:38
169.1-266	Lab Room 130 East Wall North Sink Left	Sink	9:40
169.1-267	Lab Room 130 East Wall North Sink Right	Sink	9:42
169.1-268	Lab Room 130 East Wall Center Sink Left	Sink	9:44
169.1-269	Lab Room 130 East Wall Center Sink Right	Sink	9:46
169.1-270	Lab Room 130 East Wall South Sink Left	Sink	9:48
169.1-271	Lab Room 130 East Wall South Sink Right	Sink	9:50

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 2/27/2021
 Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/1/2021
 Received (Name / Lab): RTHARRIS Date: 3.3.21 Time: 11:44 AM
 Sample Login (Name / Lab): Troci Bloom / Grace Bloom Date: 3/15/21 Time: 8:28 AM
 Analysis (Name / Lab): J. Hertigler Date: 3/29/21 Time: 12:23 pm
 QA/QC Review (Name / Lab): J. Fendley Date: 3/31/21 Time: 5:28 pm
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

00593



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Lancaster High School

Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
169.1-272	Prep Room 130A Left	Sink	9:52
169.1-274	Lab Room 128 Teacher Desk Left	Sink	9:54
169.1-277	Prep Room 128A Left	Sink	9:56
169.1-279	Room 126 Teacher Desk Left	Sink	9:58
169.1-280	Room 126 Teacher Desk Right	Sink	10:00
169.1-281	Room 129 Teacher Desk Left	Sink	10:02
169.1-284	Room 131A Left	Sink	10:04
169.1-286	Room 131 Teacher Desk Left	Sink	10:06
169.1-289	Lab S16 North Wall	Sink	10:08
169.1-290	Lab S16 East Wall North Sink Left	Sink	10:10
169.1-291	La S16 East Wall North Sink Right	Sink	10:12
169.1-292	Lab S16 East Wall 2nd North Sink Left	Sink	10:14
169.1-293	Lab S16 East Wall 2nd North Sink Right	Sink	10:16
169.1-294	Lab S16 East Wall 2nd South Sink Left	Sink	10:18
169.1-295	Lab S16 East Wall 2nd South Sink Right	Sink	10:20
169.1-296	Lab S16 East Wall South Sink Left	Sink	10:22
169.1-297	Lab S16 East Wall South Sink Right	Sink	10:24
169.1-298	Lab S16 South Wall East Sink Left	Sink	10:26

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 2020L-169.1

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021

Received (Name / Lab): RTHARRIS Date: OK Time: 3:30 11:44 AM

Sample Login (Name / Lab): Tina Bloom / J. B. Date: 3/15/21 Time: 8:34 AM

Analysis (Name / Lab): J. Bertzler Date: 3/29/21 Time: 12:25 pm

QA/QC Review (Name / Lab): J. E. Long Date: 3/31/21 Time: 5:25 pm

Archived / Released: QA/QC InterLAB Use: Date: Time:

DD593



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLNENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD Contact: Michael Bryniarski

Building: Lancaster High School Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
169.1-299	Lab S16 South Wall East Sink Right	Sink	10:28
169.1-300	Lab S16 South Wall Center Sink Left	Sink	10:30
169.1-301	Lab S16 South Wall Center Sink Right	Sink	10:32
169.1-302	Lab S16 South Wall Right Sink	Sink	10:34
169.1-303	Lab S16 Teachers Desk	Sink	10:36
169.1-305	Lab S15 Teachers Desk	Sink	10:38
169.1-306	Lab S15 South Wall East Sink	Sink	10:40
169.1-307	Lab S15 South Wall Center Sink Left	Sink	10:42
169.1-308	Lab S15 South Wall Center Sink Right	Sink	10:44
169.1-309	Lab S15 South Wall West Sink Left	Sink	10:46
169.1-310	Lab S15 South Wall West Sink Right	Sink	10:48
169.1-311	Lab S15 West Wall South Sink Left	Sink	10:50
169.1-312	Lab S15 West Wall South Sink Right	Sink	10:52
169.1-313	Lab S15 West Wall 2nd South Sink Left	Sink	10:54
169.1-314	Lab S15 West Wall 2nd South Sink Right	Sink	10:56
169.1-315	Lab S15 West Wall 2nd North Sink Left	Sink	10:58
169.1-316	Lab S15 West Wall 2nd North Sink Right	Sink	11:00
169.1-317	Lab S15 West Wall North Sink Left	Sink	11:02

Notes:

Please e-mail lab results to labs@stohlenv.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 2/27/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/1/2021

Received (Name / Lab): K. THARRIS JK Lab Date: 3-3-21 Time: 11:44 AM

Sample Login (Name / Lab): Amanda Lowery Date: 3/24/21 Time: 10:07 AM

Analysis (Name / Lab): J. Henderson Date: 3/29/21 Time: 12:25 pm

QA/QC Review (Name / Lab): J. Fuddy Date: 3/31/21 Time: 5:28 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

00593



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Lancaster High School

Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
169.1-318	Lab S15 West Wall North Sink Right	Sink	11:04
169.1-319	Lab S15 North Wall	Sink	11:06
169.1-320	Lab S14 North Wall	Sink	11:08
169.1-321	Lab S14 East Wall North Sink Left	Sink	11:10
169.1-322	Lab S14 East Wall North Sink Right	Sink	11:12
169.1-323	Lab S14 East Wall 2nd North Sink Left	Sink	11:14
169.1-324	Lab S14 East Wall 2nd North Sink Right	Sink	11:16
169.1-325	Lab S14 East Wall 2nd South Sink Left	Sink	11:18
169.1-326	Lab S14 East Wall 2nd South Sink Right	Sink	11:20
169.1-327	Lab S14 East Wall South Sink Left	Sink	11:22
169.1-328	Lab S14 East Wall South Sink Right	Sink	11:24
169.1-329	Lab S14 South Wall East Sink Left	Sink	11:26
169.1-330	Lab S14 South Wall East Sink Right	Sink	11:28
169.1-331	Lab S14 South Wall Center Sink Left	Sink	11:30
169.1-332	Lab S14 South Wall Center Sink Right	Sink	11:32
169.1-333	Lab S14 South Wall West Sink	Sink	11:34
169.1-334	Lab S14 Teacher Desk	Sink	11:36
169.1-336	Lab S13 Teacher Desk	Sink	11:38

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 2/27/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/1/2021

Received (Name / Lab): RTHARRIS Date: 3-3-21 Time: 11:44 AM

Sample Login (Name / Lab): Amanda Lowery Date: 3/25/21 Time: 8:42 AM

Analysis (Name / Lab): J. Hertzler Date: 3/29/21 Time: 12:25 pm

QA/QC Review (Name / Lab): J. Eddy Date: 3/31/21 Time: 5:28 pm

Archived / Released: QA/QC InterLAB Use: Date: Time:

D0593



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Lancaster High School

Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
169.1-337	Lab S13 South Wall East Sink	Sink	11:40
169.1-338	Lab S13 South Wall Center Sink Left	Sink	11:42
169.1-339	Lab S13 South Wall Center Sink Right	Sink	11:44
169.1-340	Lab S13 South Wall West Sink Left	Sink	11:46
169.1-341	Lab S13 South Wall West Sink Right	Sink	11:48
169.1-342	Lab S13 West Wall South Sink Left	Sink	11:50
169.1-343	Lab S13 West wall South Sink Right	Sink	11:52
169.1-344	Lab S13 West Wall 2nd South Sink Left	Sink	11:54
169.1-345	Lab S13 West Wall 2nd South Sink Right	Sink	11:56
169.1-346	Lab S13 West Wall 2nd North Sink Left	Sink	11:58
169.1-347	Lab S13 West Wall 2nd North Sink Right	Sink	12:00
169.1-348	Lab S13 West Wall North Sink Left	Sink	12:02
169.1-349	Lab S13 West Wall North Sink Right	Sink	12:04
169.1-350	Lab S13 North Wall	Sink	12:06
169.1-351	Lab S12 North Wall	Sink	12:08
169.1-352	Lab S12 East Wall North Sink Left	Sink	12:10
169.1-353	Lab S12 East Wall North Sink Right	Sink	12:12
169.1-354	Lab S12 East Wall 2nd North Sink Left	Sink	12:14

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 2/27/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/1/2021

Received (Name / Lab): R. Harris Date: 3.3.21 Time: 11:44 AM

Sample Login (Name / Lab): Amarda Lavery Date: 3/25/21 Time: 9:13 AM

Analysis (Name / Lab): J. Kettler Date: 3/29/21 Time: 12:25 pm

QA/QC Review (Name / Lab): J. Eddy Date: 3/31/21 Time: 5:28 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

00593



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Lancaster High School

Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
169.1-355	Lab S12 East Wall 2nd North Sink Right	Sink	12:16
169.1-356	Lab S12 East Wall 2nd South Sink Left	Sink	12:18
169.1-357	Lab S12 East Wall 2nd South Sink Right	Sink	12:20
169.1-358	Lab S12 East Wall South Sink Left	Sink	12:22
169.1-359	Lab S12 East Wall South Sink Right	Sink	12:24
169.1-360	Lab S12 South Wall East Sink Left	Sink	12:26
169.1-361	Lab S12 South Wall East Sink Right	Sink	12:28
169.1-362	Lab S12 South Wall Center Sink Left	Sink	12:30
169.1-363	Lab S12 South Wall Center Sink Right	Sink	12:32
169.1-364	Lab S12 South Wall West Sink	Sink	12:34
169.1-365	Lab S12 Teacher Desk	Sink	12:36
169.1-367	Lab S11 Teacher Desk	Sink	12:38
169.1-368	Lab S11 South Wall East Sink	Sink	12:40
169.1-369	Lab S11 South Wall Center Sink Left	Sink	12:42
169.1-370	Lab S11 South Wall Center Sink Right	Sink	12:44
169.1-371	Lab S11 South Wall West Sink Left	Sink	12:46
169.1-372	Lab S11 South Wall West Sink Right	Sink	12:48
169.1-373	Lab S11 West Wall South Sink Left	Sink	12:50

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 2/27/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 3/1/2021

Received (Name / Lab): K. HARRIS Date: 3.3.21 Time: 11:47 AM

Sample Login (Name / Lab): Aminda Lowery Date: 3/25/21 Time: 9:38 AM

Analysis (Name / Lab): J. Bertzler Date: 3/29/21 Time: 12:25 pm

QA/QC Review (Name / Lab): J. Eddy Date: 3/31/21 Time: 5:28pm

Archived / Released: QA/QC InterLAB Use: Date: Time:

00593



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Lancaster High School

Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
169.1-374	Lab S11 West Wall South Sink Right	Sink	12:52
169.1-375	Lab S11 West Wall 2nd South Sink Left	Sink	12:54
169.1-376	Lab S11 West Wall 2nd South Sink Right	Sink	12:56
169.1-377	Lab S11 West Wall 2nd North Sink Left	Sink	12:58
169.1-378	Lab S11 West Wall 2nd North Sink Right	Sink	13:00
169.1-379	Lab S11 West Wall North Sink Left	Sink	13:02
169.1-380	Lab S11 West Wall North Sink Right	Sink	13:04
169.1-381	Lab S11 North Wall	Sink	13:06
169.1-382	Lab 111 Teacher Desk Left	Sink	13:08
169.1-383	Lab 111 Teacher Desk Right	Sink	13:10
169.1-384	Lab 111 West Wall South Sink Left	Sink	13:12
169.1-385	Lab 111 West Wall South Sink Right	Sink	13:14
169.1-386	Lab 111 West Wall Center Sink Left	Sink	13:16
169.1-387	Lab 111 West Wall Center Sink Right	Sink	13:18
169.1-388	Lab 111 West Wall North Sink Left	Sink	13:20
169.1-389	Lab 111 West Wall North Sink Right	Sink	13:22
169.1-390	Lab 111 East Wall North Sink Left	Sink	13:24
169.1-391	Lab 111 East Wall North Sink Right	Sink	13:26

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 2/27/2021

Relinquished By: E. Henderson Print Name Stohl Env: Eric Henderson Jr. Date: 3/1/2021

Received (Name / Lab): KT HARRIS Date: 3.3.21 Time: 11:47 AM

Sample Login (Name / Lab): Amanda Lowery Date: 3/25/21 Time: 9:57 AM

Analysis (Name / Lab): J. Henderson Date: 3/29/21 Time: 12:25 pm

QA/QC Review (Name / Lab): J. Eddy Date: 3/31/21 Time: 5:28 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

00593



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Lancaster High School

Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
169.1-392	Lab 111 East Wall Center Sink Left	Sink	13:28
169.1-393	Lab 111 East Wall Center Sink Right	Sink	13:30
169.1-394	Lab 111 East Wall South Sink Left	Sink	13:32
169.1-395	Lab 111 East Wall South Sink Right	Sink	13:34
169.1-396	Lab 111A Office Area Left	Sink	13:36
169.1-398	Lab 109 Teachers Desk	Sink	13:38
169.1-399	Lab 109 West Wall	Sink	13:40
169.1-402	Lab 109 West Row Center Sink Left	Sink	13:42
169.1-403	Lab 109 West Row Center Sink Right	Sink	13:44
169.1-404	Lab 109 West Row North Sink Left	Sink	13:46
169.1-405	Lab 109 West Row North Sink Right	Sink	13:48
169.1-406	Lab 109 East Row North Sink Left	Sink	13:50
169.1-407	Lab 109 East Row North Sink Right	Sink	13:52
169.1-408	Lab 109 East Row Center Sink Left	Sink	13:54
169.1-409	Lab 109 East Row Center Sink Right	Sink	13:56
169.1-412	Lab 107 West Wall South Sink	Sink	13:58
169.1-415	Lab 107 West Wall North Sink Left	Sink	14:00
169.1-416	Lab 107 West Wall North Sink Right	Sink	14:02

Notes:

Please e-mail lab results to labs@stohlenv.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 2/27/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/1/2021

Received (Name / Lab): KTHARRIS K. Harris Date: 3.3.21 Time: 11:48 AM

Sample Login (Name / Lab): Amara Lowery Date: 3/26/21 Time: 9:37 AM

Analysis (Name / Lab): J. Hertigler Date: 3/29/21 Time: 12:25 pm

QA/QC Review (Name / Lab): J. Easley Date: 3/31/21 Time: 5:28 pm

Archived / Released: QA/QC InterLAB Use: Date: Time:



Stohl
ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.1

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Lancaster High School

Location: 1 Forton Drive Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)	X
--	---

Turnaround

20 Days

Notes:

Please e-mail lab results to labs@stohleny.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 2/27/2021

Relinquished By: Eric Henderson Print Name Stohl Env: Eric Henderson Jr. Date: 3/1/2021

Received (Name / Lab): RTHARRIS K Davis Date: 3.3.21 Time: 11:48 AM

Sample Login (Name / Lab): Amanda H. Henry Date: 3/26/21 Time: 9:46 AM

Analysis (Name / Lab): A. Bertolero Date: 3/29/21 Time: 12:25 am

QA/QC Review (Name / Lab): D. Evers Date: 3/31/25 Time: 5:28pm

Archived / Released: QA/QC InterLAB Use: Date: Time:

BLANK

BLANK

BLANK



3860 California Road, Orchard Park, New York 14127

PHONE (716) 312-0070 FAX (716) 312-8092

WWW.STOHLENVIRONMENTAL.COM